



The Odan/Detech Group Inc.  
P: (905) 632-3811  
F: (905) 632-3363  
5230, SOUTH SERVICE ROAD, UNIT 107  
BURLINGTON, ONTARIO, L7L 5K2  
www.odandetech.com

**PROPOSED SENIOR LIVING RESIDENTIAL DEVELOPMENT  
79 HENDERSON STREET  
PORT HOPE, ONTARIO**

PROJECT No.: 21241(PH)

# **FUNCTIONAL SERVICING & STORMWATER MANAGEMENT REPORT**

OWNER:

**NAUTICAL LANDS GROUP**

Prepared By:

THE ODAN/DETECH GROUP INC.

1<sup>st</sup> Submission – January 2022

2<sup>st</sup> Submission – November 2022

## **Table of Contents**

1.0	BACKGROUND .....	1
2.0	SCOPE OF WORK .....	2
3.0	SERVICING DESIGN CONSIDERATIONS.....	2
3.1	Sanitary Wastewater Disposal .....	2
3.2	Water Distribution.....	5
3.3	Stormwater Management .....	10
4.0	EROSION CONTROL.....	14
5.0	CONCLUSIONS.....	14

## **LIST OF TABLES**

<b>Table 1 – Summary of Land Uses for Sanitary Flow Calculations.....</b>	<b>2</b>
<b>Table 2– Calculated Sanitary Sewage Flows from Proposed Development .....</b>	<b>3</b>
<b>Table 3– Summary of Sanitary Flows from the Site.....</b>	<b>4</b>
<b>Table 4– Existing Hydrant Pressure/Flow Conditions .....</b>	<b>5</b>
<b>Table 5 – Total Water Demand for the Site – FUS - .....</b>	<b>6</b>
<b>Table 6 – Total Water Demand for the Site – OBC - .....</b>	<b>9</b>
<b>Table 7 – Allowable Discharge .....</b>	<b>10</b>
<b>Table 8 – Catchment Characteristics for the Pre-Developed Site.....</b>	<b>11</b>
<b>Table 9 – Summary of Flows from Site-Pre-Development Condition.....</b>	<b>11</b>
<b>Table 10 – Storage Summary .....</b>	<b>12</b>
<b>Table 11 – Catchment Characteristics for the Post-Developed Site .....</b>	<b>13</b>
<b>Table 12 – Summary of Flows from Site .....</b>	<b>13</b>
<b>Table 13 – Summary Information.....</b>	<b>14</b>

## **APPENDIX A - SITE**

*Aerial Photo of Existing Site*  
*Site Plan*  
*Site Statistics*  
*Topography of Existing Site*

## **APPENDIX B - SANITARY**

*Sanitary Flow Calculations*

## **APPENDIX C - WATER**

*FUS Calculation Sheets*  
*OBC Calculation prepared by Jain Sustainability Consultants Inc.*  
*Fire Flow Testing Report*

## **APPENDIX D - STORM**

*Pre-Development Storm Drainage Area Plan*  
*Post-Development Storm Drainage Area Plan*  
*Stage/Storage/Discharge Calculation Sheets*  
*Cultec Stormwater Sizing Sheets (if required)*  
*Visual OTTHYMO Model*  
*Visual OTTHYMO Output*  
*OGS Sizing Report*

## **APPENDIX E**

*ODAN/DETECH Group Engineering Drawings*  
*Concept Site Servicing*  
*Concept Site Grading*


Note: This report is to be read with the Site Servicing and Site Grading Plans prepared by Odan/Detech.

## 1.0 BACKGROUND

The property under study is a 1.82 ha site located at 79 Henderson Street in Port Hope. The site is bounded by Henderson Street to the east, a grocery store to the south (Davis' Your Independent Grocer), Home Hardware Building Centre and vacant area to the west, and a vacant area to the north. Presently, the site is vacant land with vegetated cover. Refer to the Aerial Photo of the Existing Site in **Appendix A** for additional details.

It is proposed by Nautical Lands Group (NLG) to construct 36 new townhouses (no basements) and a 4-storey apartment building with 40 two-bedroom units and 34 one-bedroom units. The rest of the site will be comprised of surface parking and landscape. Refer to **Figure 1** below for further information regarding the proposed layout of the site.

In general, the property surface topography is higher in the north-east and slopes gently towards the south-west. For detailed topography of the existing site conditions, refer to **Appendix A** for the latest topographic survey prepared by Sylvester & Brown Land Surveying Ltd., dated July 23, 2021.



**Figure 1** is an Excerpt from the Architectural Site Plan, prepared by NLG. For detailed information regarding the layout of the proposed development, please refer to the latest drawings prepared by NGL. For general existing site conditions see **Appendix A**.

## 2.0 SCOPE OF WORK

THE ODAN/DETECH GROUP INC. was retained by the owner, **Nautical Lands Group**, to review the site, collect data, evaluate the site for the proposed land use and present the findings in an Engineering Report.

This report will evaluate the serviceability of the site with respect to sanitary, water and storm services and also evaluate the stormwater management (SWM) strategy that will be implemented to meet the Municipality of Port Hope design criteria.

## 3.0 SERVICING DESIGN CONSIDERATIONS

### 3.1 Sanitary Wastewater Disposal

#### Existing Condition

On the east side of the subject property, an existing 250mm diameter PVC sanitary sewer is located in the middle of Henderson St, which flows southerly towards the service corridor, where it is connected to the a 300mm diameter PVC sanitary sewer. This continues to the south-west side of the subject property where an existing 300mm diameter PVC sanitary sewer is located within a service corridor that flows northerly. At the mid-west side of the property the sewer bends and continues to flow in a westerly direction to Fox Road.

A summary of the existing and proposed land uses for the sanitary flows which outlet to Fox Road are shown in Table 1 below.

**Table 1 – Summary of Land Uses for Sanitary Flow Calculations**

Land Use	Site Area (ha)	Commercial		Residential	
		Floor Area (m <sup>2</sup> )	Total Population	No. of Units	Total Population
Existing	1.822	0	0	0	0
Proposed	1.822	0	0	110	229

### i) Pre-Development Site

For calculating the population increase for the site, the existing population was assumed to be zero because the site is vacant land.

### ii) Post-Development Site

The following Municipality of Port Hope standards for population densities and flow rates will be used to calculate the sanitary flows from the proposed development.

Residential:

- 1.4 persons/unit for 1 bedroom apartment
- 2.1 persons/unit for 2 bedroom apartment

Flow Rates:

- flow rate of 450 L/person/day – residential

The infiltration factor for the City is 0.26 L/s per hectare.

The above values are based on City of Toronto Design Guidelines as discussed with the Municipality of Port Hope Engineering Department.

Sanitary flows from the proposed development are summarized as follows.

<b>Table 2– Calculated Sanitary Sewage Flows from Proposed Development</b>	
Peak Flow from Site (L/s)	4.92
Infiltration (L/s)	0.47
<b>Total = Peak Flow + Infiltration (L/s)</b>	<b>5.39</b>

## Proposed Sanitary Servicing

### Proposed Condition

The proposed development consists of a senior living residential apartment and related senior living townhomes. Refer to the Architectural Statistics in Appendix A are provided for on the Architectural Site Plan.

The proposed site will utilize the existing sanitary sewer located on the service corridor. The site will propose a 200mm diameter sewer to capture the flow from the proposed 36 new townhouses and 74 units 4-storey apartment building. The size of the outlet sewer will be confirmed by Mechanical at the time of detailed design, adjustments may be required at that time.

Based on the population and flow rates the proposed site will have a peak flow of 5.42 L/s. The calculations for the site sanitary flows are included in **Appendix B** and are summarized below in **Table 3**.

---

---

**Table 3– Summary of Sanitary Flows from the Site**

---

Location of Outlet	Existing Peak Flow (l/s)	Proposed Peak Flow (l/s)
Henderson Street	0	5.39

---

---

## 3.2 Water Distribution

### Existing Condition

There is an existing 300mm diameter ductile iron watermain located on the east side of Henderson Street.

There are existing public fire hydrants located on the Henderson Street of the subject site which cover a portion of said site.

Hydrant flow tests for the hydrants described have been performed by SCG process on January 21<sup>st</sup> of 2022 with the following results.

**Table 4– Existing Hydrant Pressure/Flow Conditions**

Hydrant Location	Static Pressure (Psi)	Flow @ 20 Psi (USGPM)
79 Henderson Street	65.9	3338

### Proposed Condition

It is proposed to connect the site to the existing 300mm diameter watermain located on Henderson Street for domestic and fire-fighting purposes. New 200mm fire & 100mm domestic will be provided to the site.

The unit rate and peaking factors of water consumption, minimum pipe size and allowable pressure in line were established from the Municipality of Port Hope Guidelines. The fire flow water demand is calculated as per FUS 1999 manual.

The pressures and volumes must be sufficient for peak hour conditions and under fire conditions as established by the Ontario Building Code 2006. The minimal residual pressure under fire conditions is 140 kpa. (or 20.3 psi).

The firefighting calculations are based on a fire resistive rating of a sprinklered building with protected steel.

Please refer to **Appendix C** for further details.

The water demand of the proposed site is calculated as follows:

#### Residential Water Demand

a)	Average Day domestic demand -	using 270L/cap/day (229 persons, from sanitary calculations)	0.72 L/sec
b)	Peak day demand -	1.8 x daily demand	1.30 L/sec
c)	Peak hour demand -	3.0 x daily demand	2.16 L/sec
d)	Fire flow (Fire Resistive)		301.3 L/sec



**Table 5 – Total Water Demand for the Site – FUS -**

	L/sec	USGM
Peak Day Demand	1.30	20.6
Fire Flow Demand	300	4755
Total Water Demand	301.3	4776
Actual Flow at 20 PSI Residual Pressure	210.6	3338

Based on the hydrant flow testing results and as determined using the FUS method for calculating fire flows the existing main is not sufficient to service the subject development. However, since the FUS is typically used for planning purposes the required fire flows will be based on the OBC at the detailed design stage to show that adequate flows are available to service the building.

In general, a residential development requires 150 l/sec (2,378 USGPM) for fire protection. The OBC fire flow calculation for a sprinklered building is provided on the next page based on the same building from a similar development. This shows the required fire flow for this building when sprinklered. The following was provided by Jain Sustainability Consultants Inc. for a similar site proposed in Bradford, Ontario. The full report prepared by JSCI can be found in Appendix



Jan. 17, 2022

**Re: 500 Holland Street W., Bradford ON.  
Fire Protection Water Supply Requirement for Part 3 of O.B.C.**

The proposed commercial building at 500 Holland Street W., Bradford ON. is a Seniors apartment building. The entire building is of combustible construction, sprinklered.

The site and building is serviced by municipal water supply (Water flow and pressure test attached)

#### **Existing Site (attached)**

The Subject Site is located on the (short description of site and surrounding areas)

To the North: Vacant Land  
To the East: Existing Grocery Store  
To the West: Langford Blvd  
To the South: Miller Park Ave

Calculation:  $Q=KVStot$

K: building construction classification

V: building volume

Stot: building property line distances

$Stot = 1 + \sum Stot$

#### Building classifications by group:

Apartment Building: C (K=18)

#### Building Volume:

24,625 m<sup>3</sup>

#### Building multiple exposures:

18.1 m; Stot = 0

27.6 m; Stot = 0

3.0 m 1.5m, Stot=0.5

26.5 m, Stot = 0

$Stot = 1+0+0+0.5+0$

Jain Sustainability Consultants Inc.  
7405 East Danbro Crescent,  
Mississauga, Ontario, L5N 6P8 Canada

(905) 285-9900   
(905) 567-5246   
mail@jainconsultants.com   
www.jainconsultants.com 

thinking globally, delivering locally

# Jain

$Q=18 \times 24,626 \text{ m}^3 \times 1.5$

$Q=664,902 \text{ m}^3$

According to Fire protection Water Supply guideline for Part 3 of OBC A3.2.5.7, Table 2:

Minimum water supply flow rate for  $Q \geq 270,000$

Required water supply shall be 9000 L/min (150 L/sec)

Conclusion:

Municipal water supply graph shows sufficient flow and pressure used for sprinkler and inside and outside hose stream requirement as referenced by Article 3.2.5.13 of the Building Code and NFPA 13.

Yours very truly,



D. Jain, M.Eng., M.B.A., P.Eng., C.E.M., L.A.P.



Enclosures

1. Site Plan
2. Water flow and pressure test

As can be seen above and based on the OBC the water demand can be adjusted as shown in Table 6;

<b>Table 6 – Total Water Demand for the Site – OBC -</b>		
	L/sec	USGM
Peak Day Demand	1.30	20.6
Fire Flow Demand	150	2,378
Total Water Demand	151.3	2,398
Actual Flow at 20 PSI Residual Pressure	210.6	3,338

As can be seen above the existing water supply will be adequate to provide the necessary domestic and fire flow to the proposed site under the Ontario Building Code applied sprinklered building calculations. Final calculations will be provided to confirm the above by a qualified sprinkler consultant at the detailed design stage.

### 3.3 Stormwater Management

#### Existing Condition

On the south side of the subject property, there is an existing 1.0 meter flat bottom ditch, with 3:1 sloping and a minimum depth of 0.8 meters, located on a service corridor that flows westerly until the southwest corner of the property. It then continues to flow northerly for approximately 83.5 meters where it then changes direction and flows to the west towards Fox Road.

On the east side of the subject property, there is an existing ditch which flows southerly down Henderson Street, and outlets into the existing 1.0 meter flat bottom ditch on the south of the property.

The existing site drains via sheet flow to the existing 1.0 meter flat bottom ditch on service corridor.

#### Pre - Development Flows:

The allowable flows were based on criteria obtained from the Town of Port Hope during a preconsultation meeting. The design criteria provided is to control flows from the site to 17.3 l/s/ha in accordance with the *Stormwater Management and Erosion and Silt Control Report* by Aecom, (2011).

#### ***Design storm data for the Town of Port Hope:***

5 Year storm event

$$I_5 = 2464/(T_c+16)$$

where: I = intensity (mm/hr.)

$T_c$  = time of concentration (min)

100 Year storm event

$$I_{100} = 5588/(T_c+28)$$

where: I = intensity (mm/hr.)

$T_c$  = time of concentration (min)


<b>Table 7 – Allowable Discharge</b>	
<b>Total Area (ha)</b>	<b>Q (l/s) – 17.3 l/s/ha</b>
1.822	31.5

A Visual OTTHYMO is used for the modelling to determine the peak flows for 5- and 100-year storm events for the existing condition using NASHYD method, see the following Table 8 for the description and characteristics of the pre-development system. The pre-development discharge for 100-year storm event is 240 l/s however, the post-development discharge should be less or equal to the allowable discharge.

**Table 8 – Catchment Characteristics for the Pre-Developed Site**

Area No.	Area (ha)	Hydrograph Method	% impervious	imperviousness directly connected %	Loss Method for Pervious Area	CN for Pervious Area	Initial Abstraction for Pervious Area	Time to peak (T <sub>p</sub> )
Site	1.822	NASHYD	-	-	SCS	80	5	0.20

A schematic of Visual OTTHYMO Model (100 Year Storm)-pre-development condition is shown below:



The following **Table 9** shows a summary of the peak flows from the site.

**Table 9 – Summary of Flows from Site-Pre-Development Condition**

Storm Event	Allowable Flow (L/s)	Pre-Development Flow (L/s)
5 Year Storm	31.5	75
100 Year Storm	31.5	240

Refer to the Visual OTTHYMO detailed output in **Appendix D** for further details.

## Post - Development Flows:


For the purposes of post-development analysis, the proposed site has been divided into post-development tributary areas as shown in **Appendix D**

In order to control the post development flows to allowable flows, on-site storage by two underground storage chambers and a dry pond as well as a roof control for the 4-storey apartment building will be required. Visual OTTHYMO will be used to model and determine the detention volume required. A 0.10m (100mm) Orifice plate will be used to detain flows on site before discharging to the existing ditch on the west side of the property. The stage/storage/discharge properties used to model the flow controls for this site are shown in **Appendix D**. A summary of the site storage is provided in Table 10 below.

Storm	Required Storage (m <sup>3</sup> )	Provided Storage (m <sup>3</sup> )
5 Year	<b>337</b>	<b>907</b>
100 Year	<b>890</b>	<b>907</b>

Visual OTTHYMO 2.3.2. will be used to model and determine the peak flows for 5- year and 100-year storm events. For drainage areas with significant imperviousness the calculation of effective rainfall in Visual OTTHYMO is accomplished using the “STANDHYD” method. This method is used in urban watersheds to simulate runoff by combining two parallel standard unit hydrographs resulting from the effective rainfall intensity over the pervious and impervious surfaces. For pervious surfaces, losses are calculated using the SCS modified CN method.

See schematic of Visual OTTHYMO Model (100 -Year Storm) below:



**Table 11** shows the description and characteristics of the post-development system. Refer to the Visual OTTHYMO detailed output file in **Appendix D** for further details.

Area No.	Area (ha)	Hydrograph Method	% impervious	imperviousness directly connected %	Loss Method for Pervious Area	CN for Pervious Area	Initial Abstraction for Pervious Area	Time to peak (T <sub>p</sub> )
Area 1- Rooftop Controlled	0.17	STANDHYD	99	99	SCS	80	1	-
Area 2- Rooftop uncontrolled	0.323	STANDHYD	99	99	SCS	80	1	-
Area 3- Hardscape	0.699	STANDHYD	90	90	SCS	80	1	-
Area 3 - Landscape	0.629	NASHYD	-	-	SCS	80	5	0.167

The following **Table 12** shows a summary of the total peak flows from the site.

Storm Event	Allowable Flow (L/s)	Proposed Flow (L/s)
5 Year Storm	31.5	21
100 Year Storm	31.5	29

As can be seen the post development flow is less than the allowable flow for both the 2- and 100-year storm events, thus meeting the Town of Port Hope storm water quantity controls for the proposed development.

#### **Water Quality:**

For the purposes of zoning and based on the type of development water quality can be achieved through the use of an adequately sized Oil/Grit Separator or Oil/Grit Filtration Separator in combination with LID's and alternative means to achieve water quality.

Water Quality for the proposed development will be determined at the detailed design stage based on the above noted design principals to meet the required water quality storm events.

Based on the current site plan it is expected that a HydroDome HD 6 will meet the required 80% TSS removal.

For further detailed calculations refer to Appendix D.



#### 4.0 EROSION CONTROL

Erosion and sediment controls for the site will be implemented according to The Ministry of Natural Resources Guidelines on Erosion and Sediment Control for Urban Construction Sites. A detailed erosion control plan is included in the set of drawings.

#### 5.0 CONCLUSIONS

From our investigation, the site is serviceable utilizing existing sanitary, storm and watermain infrastructure adjacent to the site. The post development 2- & 100-year storm design have been maintained at the allocated flow rate for the site.

The following **Table 13** summarizes the components of the proposed development.

<b>Table 13 – Summary Information</b>	
Total Sanitary Flow (L/sec)	5.42
Total Water Demand : (L/sec)	151.3
Actual Flow at 20 PSI (L/sec)	210.6
Allowable release rate from site (L/sec) (100- year storm)	31.5
Actual release rate from site (L/sec) (100 year storm)	29
Total Storm Water Storage Required (m3)	890
Total Storm Water Storage Provided (m3)	907
Quantity Control	100mm Dia. Orifice Plate
Water Quality	Oil Grit Separator

Respectfully Submitted;  
**The Odan/Detech Group Inc.**




Nov. 10, 2022  
 Paul Hecimovic, P.Eng.

Nov. 10, 2022  
 Muwaffaq Al-Awad, M.Sc., P.Eng.

# APPENDIX A

- A1. Aerial Photo of Existing Site*
- A2. Site Plan*
- A3. Site Statistics*
- A4. Topography of Existing Site*

## A.1 Aerial Photo of Existing Site



**Appendix A – Figure 1: Aerial Photo of Existing Site** is an excerpt from Google Maps with the approximate property line shown (**red** line). For detailed information regarding the existing property line and topography site conditions, refer to the latest survey and drawings prepared by Sylvester & Brown Land Surveying Ltd., see also **Appendix A – Figure 2**.

# A.2 Site Plan



### A.3 Site Statistics

#### PORT HOPE SITE STATS:

LOT AREA = 18,218 SQM (4.5 AC)

#### PARKING:

APARTMENT BLDG = 98 SPACES

TOWNHOUSES = 56 SPACES

#### MID-RISE RESIDENTIAL BUILDING INFO:

- 4 STOREY
- 13.5M BDG HGT.
- 2148 SQM BDG AREA
- 7223 SQM GFA
- 74 UNITS PER HA.
- 11.8% LOT COVERAGE

#### UNIT MIX:

- 2 BEDRM UNITS = 40 (52%)
  - 1 BEDROOM UNITS = 34 (48%)
- TOTAL UNIT COUNT = 74

#### 5 UNIT TOWNHOUSE BLOCK COUNT: = 4 (8.8% LOT COVERAGE)

- BLOCK AREA = 402 SQM
  - 2 BEDROOM UNITS = 12
  - 1 BEDROOM UNITS = 8
- TOTAL = 20

#### 4 UNIT TOWNHOUSE BLOCK COUNT: = 4 (6.8% LOT COVERAGE)


- BLOCK AREA = 312 SQM
  - 2 BEDROOM UNITS = 8
  - 1 BEDROOM UNITS = 8
- TOTAL = 16

TOTAL TOWNHOUSE UNIT COUNT = 36  
(TOTAL TOWNHOUSE LOT COVERAGE = 15.6%)

#### TOWNHOUSE UNIT BREAK-DOWN:

- 1) 20 TWO BEDROOM UNITS (55%)
- 2) 16 ONE BEDROOM UNITS (45%)

## A.4 Topography of Existing Site



**Appendix A – Figure 2: Topography of Existing Site** is topography from Drawing 20-2716, dated July 23, 2021 and prepared by Sylvester & Brown Land Surveying Ltd. For detailed information regarding the existing topography site conditions, refer to the latest survey and drawings prepared by Sylvester & Brown Land Surveying Ltd.

# APPENDIX B

## *SANITARY FLOW CALCULATIONS*

SANITARY FLOW CALCULATIONS				SCENERIO:		Proposed/Existing Development		
This program calculates the sanitary discharge from various land use								
As per the City of Toronto Guidelines				FILL IN COLOURED CELLS AS REQUIRED				
TOTAL SITE AREA (ha) =		1.822						
LAND USE	NUMBER OF UNITS	SITE AREA, (ha)	GROSS FLOOR AREA, m2	TOTAL POPULATION	TOTAL DAILY FLOW (LITERS)	AVERAGE DAILY FLOW l/sec	PEAKING FACTOR, M	TOTAL FLOW FROM LAND USE, l/sec
RESIDENTIAL EX 1 Bedroom, using 1.4 persons/unit	0			0	0	0.00		
RESIDENTIAL PROP 1 Bedroom, using 1.4 persons/unit	34			48	21420	0.25		
RESIDENTIAL EX 2 Bedroom, using 2.1 persons/unit	0			0	0	0.00		
RESIDENTIAL PROP 2 Bedroom, using 2.1 persons/unit	40			84	37800	0.44		
RESIDENTIAL EX 3 Bedroom using 3.1 persons/unit	0			0	0	0.00		
RESIDENTIAL PROP 3 Bedroom using 3.1 persons/unit	0			0	0	0.00		
RESIDENTIAL EX Townhouse using 2.7persons/unit	0			0	0	0.00		
RESIDENTIAL PROP TH using 2.7persons/unit	36			97	43740	0.51		
<b>Total Residential</b>	110			229	102960	1.19	4.13	4.92
COMMERCIAL, Using 100 persons/ha	0			0				
COMMERCIAL, Using 1.1 persons/100 m2	0			0				
OFFICES, Using, 3.3 persons/100m2	0			0				
<b>Total ICI</b>	0	0.00			0	0.00		0.00
<b>TOTAL</b>				P=	229			
				V1=	102960	Q1=	4.92	
						Q2=	0.00	
Q = (MqP/86400) + A * i (L/sec)						Qinfil	0.47	
						Qtot	5.39	
Q1= total flow from Residential Land Use (L/sec)			where :	P is population				
Q2= total flow from Commercial Land Use (L/sec)				q = 240 L/cap/day (Ex Residential)				
Qinfil = total flow from infiltration (L/sec)				q = 250 L/cap/day (Ex Commerical/Office)				
Qtot = total flow (Land use + infiltration)				q = 450 L/cap/day (Proposed)				
V1= Total Volume from Land Use in liters				A = gross site area				
				i = 0.26 L/sec/ha (infiltration rate)				
				Peaking Factor M = 1 + [14 / (4 + (P/1000, 1/2))]				




# APPENDIX C


*FUS CALCULATION SHEET*

*OBC CALCULATION by JSCI*

WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY  
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS


$F = 220 \times C \times \sqrt{A}$   
Where:  
 $F$  = required fire flow in liters per minute  
 $C$  = Coefficient related to the type of construction  
 $A$  = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope			PROJECT:	4 Storey Mid rise building		
OBC OCCUPANCY:	Residential			PROJECT No:	21241 (PH)		
BUILDING FOOT PRINT (m2):	2121				Contents	Charge	
# OF STOREYS	4				Non-Combustible	-25%	
CONSTRUCTION CLASS:	Wood Frame				Limited Combustible	-15%	
					Combustible	0%	
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Free Burning	15%		
NFPA 13 sprinkler standard	Yes	30%	50%	Rapid Buring	25%		
Standard Water Supply	Yes	10%			Coefficient related to type of construction		
Fully Supervised System	Yes	10%			1.5	Wood Frame	
		50%			1	Ordinary	
CONTENTS FACTOR:	Limited Combustible			CHARGE:	-15%		
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	>45	0	Separation	Charge		
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	>45	0	0-3 m	25%		
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	14.3	15	3.1 - 10 m	20%		
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	21.7	10	10.1 - 20 m	15%		
				20.1 - 30 m	10%		
				30.1 - 45 m	5%		
				> 45 m	0%		
				Firewall	10%		
				Total:	25		
					no more than 75%		
ARE BUILDINGS CONTIGUOUS:	NO						
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?			NO			
CALCULATIONS	C =	1.5	Wood Frame				
	A =	7153	m2	Total			
	F =	27909	L/min		STOREY AREAS m2		
Round to Nearest 1000 L/min	F =	28000	L/min	must be > 2000 L/min	2121	1	
					1677	2	
					1677	3	
					1677	4	
CORRECTION FACTORS:							
OCCUPANCY		-4200	L/min				
FIRE FLOW ADJUSTED FOR OCCUPANCY		23800	L/min				
REDUCTION FOR SPRINKLER		-11900	L/min				
EXPOSURE CHARGE		5950	L/min				
REQUIRED FIRE FLOW	F =	17850	L/min				
Round to Nearest 1000 L/min	F =	18000	L/min	4755	usgm		
	F =	300	L/sec				

WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS									
<b><math>F = 220 \times C \times \sqrt{A}</math></b> Where: $F$ = required fire flow in liters per minute $C$ = Coefficient related to the type of construction $A$ = the total floor area in square meters (excluding basements) in the building considered									
LOCATION:	79 Henderson Street, Port Hope				PROJECT:	4 Unit Blook			
OBC OCCUPANCY:	Residential				PROJECT No:	21241 (PH)			
BUILDING FOOT PRINT (m2):	312					Contents	Charge		
# OF STOREYS	1					Non-Combustible	-25%		
						Limited Combustible	-15%		
						Combustible	0%		
CONSTRUCTION CLASS:	Wood Frame				Free Burning	15%			
AUTOMATED SPRINKLER PROTECTION		Credit	Total		Rapid Buring	25%			
NFPA 13 sprinkler standard	No	0%	0%		Coefficient related to type of construction				
Standard Water Supply	No	0%			1.5	Wood Frame			
Fully Supervised System	No	0%			1	Ordinary			
		0%			0.8	Non combustible			
					0.6	Fire Resistive			
CONTENTS FACTOR:	Limited Combustible				CHARGE:	-15%			
EXPOSURE 1 (south)	Distance to Exposure Building (m)			22.6	10	Separation	Charge		
	Length - Height					0-3 m	25%		
EXPOSURE 2 (east)	Distance to Exposure Building (m)			>45	0	3.1 -10 m	20%		
	Length - Height					10.1 - 20 m	15%		
EXPOSURE 3 (west)	Distance to Exposure Building (m)			3.6	20	20.1 - 30 m	10%		
	Length - Height					30.1 - 45	5%		
EXPOSURE 4 (north)	Distance to Exposure Building (m)			>45	0	> 45 m	0%		
	Length - Height					Firewall	10%		
				Total:	30	no more than 75%			
ARE BUILDINGS CONTIGUOUS:	NO								
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?				NO				
CALCULATIONS	C =	1.5	Wood Frame						
	A =	312	m2	Total	STOREY AREAS m2				
	F =	5829	L/min		312	1			
Round to Nearest 1000 L/min	F =	6000	L/min	must be > 2000 L/min	0				
					0				
					0				
CORRECTION FACTORS:									
	OCCUPANCY	-900	L/min						
	FIRE FLOW ADJUSTED FOR OCCUPANCY	5100	L/min						
	REDUCTION FOR SPRINKLER	0	L/min						
	EXPOSURE CHARGE	1530	L/min						
REQUIRED FIRE FLOW	F =	6630	L/min						
Round to Nearest 1000 L/min	F =	7000	L/min	1849 usgm					
	F =	117	L/sec						


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY  
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$   
Where:  
 $F$  = required fire flow in liters per minute  
 $C$  = Coefficient related to the type of construction  
 $A$  = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	4 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	312			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	22.6	10	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	3.6	20	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	20.9	10	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	>45	0	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	40	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?			NO	
CALCULATIONS	C =	1.5	Wood Frame		
	A =	312	m2	Total	STOREY AREAS m2
	F =	5829	L/min		312
Round to Nearest 1000 L/min	F =	6000	L/min	must be > 2000 L/min	0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-900	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5100	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2040	L/min			
REQUIRED FIRE FLOW	F =	7140	L/min		
Round to Nearest 1000 L/min	F =	7000	L/min	1849	usgm
	F =	117	L/sec		


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY  
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$   
Where:  
 $F$  = required fire flow in liters per minute  
 $C$  = Coefficient related to the type of construction  
 $A$  = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	4 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	312			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	21.8	10	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	>45	0	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	3.6	20	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	22.6	10	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	40	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	312 m2	Total		STOREY AREAS m2
	F =	5829 L/min			312
Round to Nearest 1000 L/min	F =	6000 L/min	must be > 2000 L/min		0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-900	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5100	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2040	L/min			
REQUIRED FIRE FLOW	F =	7140 L/min			
Round to Nearest 1000 L/min	F =	7000 L/min	1849 usgm		
	F =	117 L/sec			


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY  
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$   
Where:  
 $F$  = required fire flow in liters per minute  
 $C$  = Coefficient related to the type of construction  
 $A$  = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	4 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	312			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	23.0	10	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	3.6	20	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	16.8	15	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	22.6	10	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	55	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	312	m2	Total	STOREY AREAS m2
	F =	5829	L/min		312
Round to Nearest 1000 L/min	F =	6000	L/min	must be > 2000 L/min	0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-900	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5100	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2805	L/min			
REQUIRED FIRE FLOW	F =	7905	L/min		
Round to Nearest 1000 L/min	F =	8000	L/min	2113	usgm
	F =	133	L/sec		


WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY  
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$   
Where:  
 $F$  = required fire flow in liters per minute  
 $C$  = Coefficient related to the type of construction  
 $A$  = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	5 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	402			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	3.6	20	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	16.8	15	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	>45	0	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	>45	0	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	35	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?			NO	
CALCULATIONS	C =	1.5	Wood Frame		
	A =	402	m2	Total	STOREY AREAS m2
	F =	6616	L/min		402
Round to Nearest 1000 L/min	F =	7000	L/min	must be > 2000 L/min	0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY		-1050	L/min		
FIRE FLOW ADJUSTED FOR OCCUPANCY		5950	L/min		
REDUCTION FOR SPRINKLER		0	L/min		
EXPOSURE CHARGE		2082.5	L/min		
REQUIRED FIRE FLOW	F =	8033	L/min		
Round to Nearest 1000 L/min	F =	8000	L/min	2113	usgm
	F =	133	L/sec		

WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY  
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS


$F = 220 \times C \times \sqrt{A}$   
Where:  
 $F$  = required fire flow in liters per minute  
 $C$  = Coefficient related to the type of construction  
 $A$  = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	5 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	402			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	7.3	20	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	29.6	10	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	>45	0	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	3.6	20	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	50	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	402 m2	Total		STOREY AREAS m2
	F =	6616 L/min			402
Round to Nearest 1000 L/min	F =	7000 L/min	must be > 2000 L/min		0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-1050	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5950	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2975	L/min			
REQUIRED FIRE FLOW	F =	8925 L/min			
Round to Nearest 1000 L/min	F =	9000 L/min	2378 usgm		
	F =	150 L/sec			




WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY  
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$   
Where:  
 $F$  = required fire flow in liters per minute  
 $C$  = Coefficient related to the type of construction  
 $A$  = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	5 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	402			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	3.6	20	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	14.2	15	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	> 45	0	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	7.3	20	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	55	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	402 m2	Total		STOREY AREAS m2
	F =	6616 L/min			402
Round to Nearest 1000 L/min	F =	7000 L/min	must be > 2000 L/min		0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-1050	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5950	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	3272.5	L/min			
REQUIRED FIRE FLOW	F =	9223 L/min			
Round to Nearest 1000 L/min	F =	9000 L/min	2378 usgm		
	F =	150 L/sec			

WATER SUPPLY FOR PUBLIC FIRE PROTECTION , FIRE UNDERWRITERS SURVEY  
GUIDE FOR DETERMINATION OF REQUIRED FIRE FLOWS

$F = 220 \times C \times \sqrt{A}$   
Where:  
*F* = required fire flow in liters per minute  
*C* = Coefficient related to the type of construction  
*A* = the total floor area in square meters (excluding basements) in the building considered

LOCATION:	79 Henderson Street, Port Hope		PROJECT:	5 Unit Blook	
OBC OCCUPANCY:	Residential		PROJECT No:	21241 (PH)	
BUILDING FOOT PRINT (m2):	402			Contents	Charge
# OF STOREYS	1			Non-Combustible	-25%
				Limited Combustible	-15%
				Combustible	0%
CONSTRUCTION CLASS:	Wood Frame			Free Burning	15%
				Rapid Buring	25%
AUTOMATED SPRINKLER PROTECTION		Credit	Total	Coefficient related to type of construction	
NFPA 13 sprinkler standard	No	0%	0%	1.5	Wood Frame
Standard Water Supply	No	0%		1	Ordinary
Fully Supervised System	No	0%		0.8	Non combustible
		0%		0.6	Fire Resistive
CONTENTS FACTOR:	Limited Combustible		CHARGE:	-15%	
EXPOSURE 1 (south)	Distance to Exposure Building (m) Length - Height	> 45	0	Separation	Charge
EXPOSURE 2 (east)	Distance to Exposure Building (m) Length - Height	27.7	10	0-3 m	25%
EXPOSURE 3 (west)	Distance to Exposure Building (m) Length - Height	26.8	10	3.1 -10 m	20%
EXPOSURE 4 (north)	Distance to Exposure Building (m) Length - Height	3.6	20	10.1 - 20 m	15%
				20.1 - 30 m	10%
				30.1 - 45	5%
				> 45 m	0%
				Firewall	10%
			Total:	40	no more than 75%
ARE BUILDINGS CONTIGUOUS:	NO				
FIRE RESISTANT BUILDING	Are vertical openings and exterior vertical communications protected with a minimum one (1) hr rating?		NO		
CALCULATIONS	C =	1.5	Wood Frame		
	A =	402 m2	Total		STOREY AREAS m2
	F =	6616 L/min			402
Round to Nearest 1000 L/min	F =	7000 L/min	must be > 2000 L/min		0
					0
					0
CORRECTION FACTORS:					
OCCUPANCY	-1050	L/min			
FIRE FLOW ADJUSTED FOR OCCUPANCY	5950	L/min			
REDUCTION FOR SPRINKLER	0	L/min			
EXPOSURE CHARGE	2380	L/min			
REQUIRED FIRE FLOW	F =	8330 L/min			
Round to Nearest 1000 L/min	F =	8000 L/min	2113 usgm		
	F =	133 L/sec			



Jan. 17, 2022

Re: 500 Holland Street W., Bradford ON.  
Fire Protection Water Supply Requirement for Part 3 of O.B.C.

The proposed commercial building at 500 Holland Street W., Bradford ON. is a Seniors apartment building. The entire building is of combustible construction, sprinklered.

The site and building is serviced by municipal water supply (Water flow and pressure test attached)

#### Existing Site (attached)

The Subject Site is located on the (short description of site and surrounding areas)

To the North: Vacant Land  
To the East: Existing Grocery Store  
To the West: Langford Blvd  
To the South: Miller Park Ave

Calculation:  $Q=KVStot$

K: building construction classification

V: building volume

Stot: building property line distances

$Stot = 1 + \sum Stot$

#### Building classifications by group:

Apartment Building: C (K=18)

#### Building Volume:

24,625 m<sup>3</sup>

#### Building multiple exposures:

18.1 m; Stot = 0





27.6 m; Stot = 0

3.0 m 1.5m, Stot=0.5

26.5 m, Stot = 0

$Stot = 1+0+0+0.5+0$

Jain Sustainability Consultants Inc.  
7405 East Danbro Crescent,  
Mississauga, Ontario, L5N 6P8 Canada

(905) 285-9900   
(905) 567-5246   
mail@jainconsultants.com   
www.jainconsultants.com 

thinking globally, delivering locally

# Jain

$Q=18 \times 24,626 \text{ m}^3 \times 1.5$

$Q=664,902 \text{ m}^3$

According to Fire protection Water Supply guideline for Part 3 of OBC A3.2.5.7, Table 2:

Minimum water supply flow rate for  $Q \geq 270,000$

Required water supply shall be 9000 L/min (150 L/sec)

Conclusion:

Municipal water supply graph shows sufficient flow and pressure used for sprinkler and inside and outside hose stream requirement as referenced by Article 3.2.5.13 of the Building Code and NFPA 13.

Yours very truly,



D. Jain, M.Eng., M.B.A., P.Eng., C.E.M., L.A.P.



Enclosures

1. Site Plan
2. Water flow and pressure test



**FLOWMETRIX**  
INDU-TECH  
PROCESS

**Fire Flow Testing Report**

Residual Hydrant #  
N.F.P.A. Colour Code

**HY**  
**BLUE**

DATE: January 25, 2022  
TIME: 10:00 AM  
ADDRESS: 79 Henderson Street  
Port Hope, ON  
L1A 2G3

**RESIDUAL HYDRANT INFO.**

HYDRANT # \_\_\_\_\_ HY \_\_\_\_\_  
N.F.P.A. COLOUR CODE \_\_\_\_\_ BLUE \_\_\_\_\_  
STATIC PRESSURE \_\_\_\_\_ 65.9 psi  
RESIDUAL PRESSURE \_\_\_\_\_ 54.2 psi  
PRESSURE DROP \_\_\_\_\_ 11.1 psi  
% PRESSURE DROP \_\_\_\_\_ 16.8 % psi  
Flow on Water Main At Test Hydrant - 20 psi 3338 USGPM


**CONTACT INFO**

Angela Mariani  
Nautical Lands Group  
T: (905) 683-1261  
E: [angela@nlgc.com](mailto:angela@nlgc.com)

**FLOW HYDRANT(S) INFO.**


HYDRANT ASSET ID	HYD. # PORTS	OUTLET DIAMETER (INCHES)	NOZZLE COEFFICIENT	DIFFUSER TYPE	DIFFUSER COEFFICIENT	PITOT READING (psi)	PITOT FLOW (USGPM)	FLOW METER (USGPM)
HY	2	2.5	Round	LPD250	0.90	26.3	775	0
		2.5	Round	LPD250	0.90	26.3	775	0
Total Flow (USGPM)							1549	0
Total Flow (USGPM)							1549	

**FIRE FLOW CHART**



**COMMENTS**

OPERATOR \_\_\_\_\_ FNX \_\_\_\_\_ Ryan Ritchie  
OPERATOR \_\_\_\_\_ FNX \_\_\_\_\_  
OPERATOR \_\_\_\_\_ Port Hope Municipality



**PART OF LOT 12  
CONCESSION 6  
CITY OF BRADFORD**

ALL INFORMATION AND DATA ON THIS PLAN IS DERIVED FROM THE PLAN PREPARED BY THE OFFICES OF SPECTRUM LAND SERVICES & DESIGN LIMITED DESIGN LAND SURVEYORS

**BRADFORD SITE STATS:**  
 LOT AREA = 2.35 ACRES  
 110 PARKING SPACES  
**MID-RISE RESIDENTIAL BUILDING INFO:**  
 - 4 STOREY  
 - 13.5M BLDG HGT.  
 - 2121 SQM BLDG AREA  
 - 7152 SQM GFA  
 - 74 UNITS PER HA.  
 - 19.7% LOT COVERAGE

**UNIT MIX:**  
 - 2 BEDRM UNITS = 40 (52%)  
 - 1 BEDROOM UNITS = 34 (48%)  
**TOTAL UNIT COUNT = 74**

**ZONING MATRIX:**

ZONING	REQUIRED	PROPOSED	COMPLIANCE
MINIMUM LOT AREA	185sqm PER DWELLING UNIT (74 UNITS x 185sqm = 13,690sqm MN)	10,356.6sqm	NO
MINIMUM LOT FRONTAGE	30.0m	145.98m	YES
MINIMUM FRONT YARD	6.0m	21.4m	YES
MINIMUM REAR YARD	7.5m	20.4m	YES
MINIMUM INTERIOR SIDE YARD	3.0m	4.1m	YES
MINIMUM EXTERIOR SIDE YARD	5.0m	34.2m	YES
MAXIMUM BUILDING HEIGHT	11.5m	13.8m	NO
PARKING	2.5 SPACES PER DWELLING UNIT	1.0 SPACES PER DWELLING UNIT	NO
VISITOR PARKING	0.25 SPACES PER DWELLING UNIT	0.25 SPACES PER DWELLING UNIT	NO

OVERALL SITE PLAN  
SCALE = 1:1000

WELLINGS SITE PLAN  
SCALE = 1:250

	PROJECT: WELLINGS OF BRADFORD LOCATION: BRADFORD, ONT. DRAWING: CONCEPTUAL SITE PLAN	DATE: FEB 2021 SCALE: 1:400 DRAWN BY: M.W. PROJECT NO.: 1925	<b>A-1</b>
	CHECKED BY: [ ] DATE: [ ] APPROVED BY: [ ] DATE: [ ]	CHECKED BY: [ ] DATE: [ ] APPROVED BY: [ ] DATE: [ ]	

## APPENDIX D

*PRE-DEVELOPMENT STORM DRAINAGE AREA PLAN*

*POST-DEVELOPMENT STORM DRAINAGE AREA PLAN*

*STAGE/STORAGE/DISCHARGE CALCULATION SHEETS*


*CULTEC DESIGN SHEET*

*VISUAL OTTHYMO MODEL-Pre-Development*


*VISUAL OTTHYMO MODEL-Post-Development*

*VISUAL OTTHYMO OUTPUT-Pre-Development*







*VISUAL OTTHYMO OUTPUT-Post-Development*







**LEGEND**

- 
PAVED AREA (0.699 ha)
- 
ROOF AREA (0.493 ha)
- 
GRAVEL AREA (0.000 ha)
- 
LANDSCAPE AREA (0.629 ha)
- 
LANDSCAPE AREA (0.000 ha)  
\*OUTSIDE OF CATCHMENT AREA\*
- 
CATCHMENT BOUNDARY

<b>DRAWING :</b>		
<b>POST-DEVELOPMENT FIGURE</b>		
DATE:	PROJ. NO.:	SCALE:
NOVEMBER 2021	21241	1:1000
<b>PROJECT :</b>		
<b>RESIDENTIAL DEVELOPMENT</b> 78 HENDERSON STREET PORT HOPE, ONTARIO		



The Odan/Detech Group Inc. P: (905) 632-3811 F: (905) 632-3363  
6230 SOUTH SERVICE ROAD, BURLINGTON, ONTARIO, L7L 5K2

## ORIFICE DISCHARGE CALCULATOR

This program calculates the discharge from a circular orifice when given elevations and orifice diameters by the user.

Discharge based on orifice equation:  $Q = CA \times \text{sqrt}(2gh)$

Orifice Diameter = **0.100** m ← Enter the orifice diameter in metres  
 Area **0.00785** m<sup>2</sup>  
 Discharge Coeff. = **0.620** ← Enter discharge Coeff. to use Orifice Plate

Elev.	Head (m)	Q (m <sup>3</sup> /s)	Total Storage(m <sup>3</sup> )
140.56	0	0.0000	0
141.20	0.64	0.0173	146.36
141.40	0.84	0.0198	275.50
141.60	1.04	0.0220	406.90
141.80	1.24	0.0240	539.00
142.00	1.44	0.0259	665.80
142.20	1.64	0.0276	788.50
142.40	1.84	0.0293	906.70

**Stage – Total Storage Table**

Elevation	Storage				
	Two Chambers	Pond	Manholes	Total	Total
m	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	m <sup>3</sup>	(ha.m)
140.9	0	0	0	0	0
141.2	65.8	76.26	4.3	146.36	0.014636
141.4	118.8	149.7	7.0	275.5	0.02755
141.6	168.8	228.4	9.7	406.9	0.04069
141.8	214.0	312.5	12.5	539	0.0539
142.0	248.4	402.2	15.2	665.8	0.06658
142.2	273.0	497.6	17.9	788.5	0.07885
142.4	287.0	599.1	20.6	906.7	0.09067

<b>POND – Stage Storage Table</b>				
ELEV.	Area	Depth (H)	Conic Inc. Vol.	Conic Total Vol.
	m2	m	m3	m3
140.9	0	N/A	N/A	0
141.0	330.89	0.069	7.61	7.61
141.1	342.88	0.1	33.69	41.30
141.2	355.14	0.1	34.90	76.20
141.3	367.66	0.1	36.14	112.33
141.4	380.45	0.1	37.40	149.74
141.5	393.49	0.1	38.70	188.43
141.6	406.80	0.1	40.01	228.45
141.7	420.38	0.1	41.36	269.80
141.8	434.22	0.1	42.73	312.53
141.9	448.32	0.1	44.12	356.66
142.0	462.68	0.1	45.55	402.20
142.1	477.31	0.1	47.00	449.20
142.2	492.20	0.1	48.47	497.68
142.3	507.35	0.1	49.98	547.65
142.4	522.77	0.1	51.50	599.16



# CULTEC Stormwater Design Calculator

Date:	January 17, 2022
<b>Project Information:</b>	
21241 - PORT HOPE	

**INPUT INFO**

<b>Calculations Performed By:</b>	
Odan Detech	

## RECHARGER 360HD

Recharger 360HD Chamber Specifications		
Height	914	mm
Width	1524	mm
Length	1.27	meters
Installed Length	1.12	meters
Bare Chamber Volume	1.04	cu. meters
Installed Chamber Volume	1.81	cu. meters




Breakdown of Storage Provided by Recharger 360HD Stormwater System		
Within Chambers	72.35	cu. meters
Within Feed Connectors	0.78	cu. meters
Within Stone	70.85	cu. meters
<b>Total Storage Provided</b>	<b>144.0</b>	<b>cu. meters</b>
Total Storage Required	120.00	cu. meters

## Materials List

Recharger 360HD		
<b>Total Number of Chambers Required</b>	<b>64</b>	<b>pieces</b>
Chamber Units	64	pieces
End Caps	32	pieces
HVLV FC-48 Feed Connectors	30	pieces
CULTEC No. 410 Non-Woven Geotextile	560	sq. meters
CULTEC No. 4800 Woven Geotextile	59	meters
Stone	177	cu. meters


Based on 2 Internal Manifolds

## Bed Detail



Bed Layout Information		
Number of Rows Wide	16	pieces
Number of Chambers Long	4	pieces
Chamber Row Width	28.96	meters
Chamber Row Length	5.24	meters
Bed Width	29.57	meters
Bed Length	5.85	meters
Bed Area Required	172.84	sq. meters
Length of Separator Row	N/A	meters

Bed detail for reference only. Not project specific. Not to scale.



Conceptual graphic only. Not job specific.

[CLICK FOR STAGE-STORAGE REPORT](#)

Cross Section Table Reference			
A	Depth of Stone Base	229	mm
B	Chamber Height	914	mm
C	Depth of Stone Above Units	305	mm
D	Depth of 95% Compacted Fill	305	mm
E	Max. Depth Allowed Above the Chamber	3.66	meters
F	Chamber Width	1524	mm
G	Center to Center Spacing	1.83	meters
H	Effective Depth	1.45	meters
I	Bed Depth	1.75	meters

**Recharger 360HD Incremental Storage Volumes**

Height of System		Chamber Volume		HVLV Feed Connector Volume		Stone Volume		Cumulative Storage Volume		Total Cumulative Storage Volume		Elevation	
in	mm	ft <sup>3</sup>	m <sup>3</sup>	ft <sup>3</sup>	m <sup>3</sup>	ft <sup>3</sup>	m <sup>3</sup>	ft <sup>3</sup>	m <sup>3</sup>	ft <sup>3</sup>	m <sup>3</sup>	ft	m
57.0	1448	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	5067.84	143.50	4.750	142.29
56.0	1422	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	5005.82	141.75	4.670	142.26
55.0	1397	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4943.81	139.99	4.580	142.24
54.0	1372	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4881.79	138.24	4.500	142.21
53.0	1346	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4819.78	136.48	4.420	142.19
52.0	1321	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4757.76	134.72	4.330	142.16
51.0	1295	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4695.75	132.97	4.250	142.14
50.0	1270	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4633.73	131.21	4.170	142.11
49.0	1245	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4571.71	129.46	4.080	142.08
48.0	1219	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4509.70	127.70	4.000	142.06
47.0	1194	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4447.68	125.94	3.920	142.03
46.0	1168	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	4385.67	124.19	3.830	142.01
45.0	1143	5.5	0.2	0.0	0.0	59.8	1.7	65.290	1.8	4323.65	122.43	3.750	141.98
44.0	1118	11.5	0.3	0.0	0.0	57.4	1.6	68.937	2.0	4258.36	120.58	3.670	141.96
43.0	1092	17.2	0.5	0.0	0.0	55.2	1.6	72.312	2.0	4189.43	118.63	3.580	141.93
42.0	1067	28.7	0.8	0.0	0.0	50.5	1.4	79.249	2.2	4117.12	116.58	3.500	141.91
41.0	1041	36.3	1.0	0.0	0.0	47.5	1.3	83.769	2.4	4037.87	114.34	3.420	141.88
40.0	1016	42.0	1.2	0.0	0.0	45.2	1.3	87.205	2.5	3954.10	111.97	3.330	141.86
39.0	991	46.8	1.3	0.0	0.0	43.3	1.2	90.091	2.6	3866.89	109.50	3.250	141.83
38.0	965	51.0	1.4	0.0	0.0	41.6	1.2	92.612	2.6	3776.80	106.95	3.170	141.81
37.0	940	54.7	1.6	0.0	0.0	40.1	1.1	94.864	2.7	3684.19	104.32	3.080	141.78
36.0	914	58.1	1.6	0.0	0.0	38.8	1.1	96.905	2.7	3589.33	101.64	3.000	141.75
35.0	889	61.3	1.7	0.0	0.0	37.5	1.1	98.776	2.8	3492.42	98.89	2.920	141.73
34.0	864	64.1	1.8	0.0	0.0	36.4	1.0	100.498	2.8	3393.65	96.10	2.830	141.70
33.0	838	67.1	1.9	0.0	0.0	35.2	1.0	102.289	2.9	3293.15	93.25	2.750	141.68
32.0	813	69.6	2.0	0.0	0.0	34.2	1.0	103.780	2.9	3190.86	90.35	2.670	141.65
31.0	787	71.9	2.0	0.0	0.0	33.2	0.9	105.171	3.0	3087.08	87.42	2.580	141.63
30.0	762	74.1	2.1	0.0	0.0	32.4	0.9	106.482	3.0	2981.91	84.44	2.500	141.60
29.0	737	76.2	2.2	0.0	0.0	31.5	0.9	107.719	3.1	2875.43	81.42	2.420	141.58
28.0	711	78.1	2.2	0.0	0.0	30.8	0.9	108.891	3.1	2767.71	78.37	2.330	141.55
27.0	686	80.0	2.3	0.0	0.0	30.0	0.9	110.002	3.1	2658.82	75.29	2.250	141.53
26.0	660	81.4	2.3	0.0	0.0	29.4	0.8	110.870	3.1	2548.81	72.17	2.170	141.50
25.0	635	83.1	2.4	0.0	0.0	28.8	0.8	111.877	3.2	2437.94	69.03	2.080	141.48
24.0	610	84.7	2.4	0.0	0.0	28.1	0.8	112.842	3.2	2326.07	65.87	2.000	141.45
23.0	584	86.2	2.4	0.0	0.0	27.5	0.8	113.760	3.2	2213.22	62.67	1.920	141.42
22.0	559	87.7	2.5	0.0	0.0	26.9	0.8	114.636	3.2	2099.46	59.45	1.830	141.40
21.0	533	88.8	2.5	0.0	0.0	26.5	0.8	115.282	3.3	1984.83	56.20	1.750	141.37
20.0	508	90.1	2.6	0.0	0.0	26.0	0.7	116.085	3.3	1869.55	52.94	1.670	141.35
19.0	483	91.4	2.6	0.0	0.0	25.5	0.7	116.854	3.3	1753.46	49.65	1.580	141.32
18.0	457	92.3	2.6	0.0	0.0	25.1	0.7	117.399	3.3	1636.61	46.34	1.500	141.30
17.0	432	93.5	2.6	0.0	0.0	24.6	0.7	118.103	3.3	1519.21	43.02	1.420	141.27
16.0	406	94.6	2.7	0.0	0.0	24.2	0.7	118.779	3.4	1401.11	39.67	1.330	141.25
15.0	381	95.7	2.7	0.0	0.0	23.7	0.7	119.424	3.4	1282.33	36.31	1.250	141.22
14.0	356	96.4	2.7	0.0	0.0	23.5	0.7	119.855	3.4	1162.90	32.93	1.170	141.20
13.0	330	97.4	2.8	0.0	0.0	23.1	0.7	120.447	3.4	1043.05	29.54	1.080	141.17
12.0	305	98.0	2.8	0.0	0.0	22.8	0.6	120.823	3.4	922.60	26.13	1.000	141.14
11.0	279	98.9	2.8	0.0	0.0	22.4	0.6	121.373	3.4	801.78	22.70	0.920	141.12
10.0	254	100.4	2.8	0.0	0.0	21.8	0.6	122.268	3.5	680.41	19.27	0.830	141.09
9.0	229	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	558.14	15.80	0.750	141.07
8.0	203	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	496.12	14.05	0.670	141.04
7.0	178	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	434.11	12.29	0.580	141.02
6.0	152	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	372.09	10.54	0.500	140.99
5.0	127	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	310.08	8.78	0.420	140.97
4.0	102	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	248.06	7.02	0.330	140.94
3.0	76	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	186.05	5.27	0.250	140.92
2.0	51	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	124.03	3.51	0.170	140.89
1.0	25	0.0	0.0	0.0	0.0	62.0	1.8	62.015	1.8	62.02	1.76	0.080	140.87
0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.000	0.0	0.00	0.00	0.000	140.84


Top of Stone Elevation

Top of Chamber Elevation


Bottom of Chamber Elevation

Bottom of Stone Elevation

## VISUAL OTTHYMO MODEL-Pre-Development



## VISUAL OTTHYMO MODEL-Post-Development



# VISUAL OTTHYMO OUTPUT-Pre-Development

```

V   V   I   SSSSS U   U   A   L
V   V   I   SS    U   U   A A  L
  V   V   I   SS    U   U   AAAAA L
  V   V   I   SS    U   U   A   A  L
   VV    I   SSSSS UUUUU A   A  LLLLL

  OOO   TTTT  TTTT  H   H   Y   Y   M   M   OOO
  O   O   T   T   H   H   Y   Y   MM MM  O   O
  O   O   T   T   H   H   Y   M   M   O   O
  OOO    T   T   H   H   Y   M   M   OOO

```

Developed and Distributed by Clarifica Inc.  
 Copyright 1996, 2007 Clarifica Inc.  
 All rights reserved.

\*\*\*\*\* D E T A I L E D O U T P U T \*\*\*\*\*

```

-----
*****
** SIMULATION NUMBER:  2 **
*****

```

```

-----
| CHICAGO STORM      |   IDF curve parameters: A=2464.000
| Ptotal= 37.70 mm  |                               B= 16.000
-----                               C= 1.000
used in:  INTENSITY = A / (t + B)^C

Duration of storm = 3.00 hrs
Storm time step   = 10.00 min
Time to peak ratio = .33

```

TIME	RAIN	TIME	RAIN	TIME	RAIN	TIME	RAIN
hrs	mm/hr	hrs	mm/hr	hrs	mm/hr	hrs	mm/hr
.17	1.53	1.00	94.77	1.83	4.54	2.67	1.39
.33	2.32	1.17	36.99	2.00	3.37	2.83	1.17
.50	3.95	1.33	17.18	2.17	2.60	3.00	1.00
.67	8.18	1.50	9.92	2.33	2.06		
.83	27.06	1.67	6.46	2.50	1.68		

```

-----
| CALIB              |
| NASHYD (0005)     |   Area      (ha)= 1.82   Curve Number (CN)= 80.0
| ID= 1 DT=10.0 min |   Ia        (mm)= 5.00   # of Linear Res.(N)= 3.00
-----
U.H. Tp (hrs)= .20

```

```

Unit Hyd Qpeak (cms)= .348

PEAK FLOW      (cms)= .075 (i)
TIME TO PEAK   (hrs)= 1.167
RUNOFF VOLUME  (mm)= 10.824
TOTAL RAINFALL (mm)= 37.696
RUNOFF COEFFICIENT = .287

```

(i) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

\*\*\*\*\*  
\*\* SIMULATION NUMBER: 6 \*\*  
\*\*\*\*\*

-----  
| CHICAGO STORM |  
Ptotal= 80.54 mm

IDF curve parameters: A=5588.000  
B= 28.000  
C= 1.000  
used in: INTENSITY = A / (t + B)^C

Duration of storm = 3.00 hrs  
Storm time step = 10.00 min  
Time to peak ratio = .33

TIME	RAIN	TIME	RAIN	TIME	RAIN	TIME	RAIN
hrs	mm/hr	hrs	mm/hr	hrs	mm/hr	hrs	mm/hr
.17	5.26	1.00	147.05	1.83	14.14	2.67	4.81
.33	7.73	1.17	77.70	2.00	10.82	2.83	4.10
.50	12.46	1.33	43.43	2.17	8.55	3.00	3.54
.67	23.45	1.50	27.74	2.33	6.93		
.83	60.52	1.67	19.25	2.50	5.73		

-----  
| CALIB |  
| NASHYD (0005) |  
ID= 1 DT=10.0 min

Area (ha)= 1.82 Curve Number (CN)= 80.0  
Ia (mm)= 5.00 # of Linear Res. (N)= 3.00  
U.H. Tp (hrs)= .20

Unit Hyd Qpeak (cms)= .348

PEAK FLOW (cms)= .240 (i)  
TIME TO PEAK (hrs)= 1.167  
RUNOFF VOLUME (mm)= 39.971  
TOTAL RAINFALL (mm)= 80.536  
RUNOFF COEFFICIENT = .496

(i) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

-----  
FINISH  
=====



# VISUAL OTTHYMO OUTPUT-Post-Development

```

=====
=====
V  V  I  SSSSS  U  U  A  L
V  V  I  SS  U  U  A  A  L
V  V  I  SS  U  U  AAAAA  L
V  V  I  SS  U  U  A  A  L
VV  I  SSSSS  UUUUU  A  A  LLLLL

OOO  TTTT  TTTT  H  H  Y  Y  M  M  OOO
O  O  T  T  H  H  Y  Y  MM  MM  O  O
O  O  T  T  H  H  Y  M  M  O  O
OOO  T  T  H  H  Y  M  M  OOO

```

Developed and Distributed by Clarifica Inc.  
 Copyright 1996, 2007 Clarifica Inc.  
 All rights reserved.

\*\*\*\*\* D E T A I L E D O U T P U T \*\*\*\*\*

```

-----
*****
** SIMULATION NUMBER: 2 **
*****

```

```

-----
| CHICAGO STORM | IDF curve parameters: A=2464.000
| Ptotal= 37.70 mm | B= 16.000
| | C= 1.000
-----
used in: INTENSITY = A / (t + B)^C

Duration of storm = 3.00 hrs
Storm time step = 10.00 min
Time to peak ratio = .33

```

TIME	RAIN	TIME	RAIN	TIME	RAIN	TIME	RAIN
hrs	mm/hr	hrs	mm/hr	hrs	mm/hr	hrs	mm/hr
.17	1.53	1.00	94.77	1.83	4.54	2.67	1.39
.33	2.32	1.17	36.99	2.00	3.37	2.83	1.17
.50	3.95	1.33	17.18	2.17	2.60	3.00	1.00
.67	8.18	1.50	9.92	2.33	2.06		
.83	27.06	1.67	6.46	2.50	1.68		

```

-----
| CALIB |
| NASHYD (0004) | Area (ha)= .63 Curve Number (CN)= 80.0
| ID= 1 DT= 5.0 min | Ia (mm)= 5.00 # of Linear Res. (N)= 3.00
-----
U.H. Tp (hrs)= .17

```

NOTE: RAINFALL WAS TRANSFORMED TO 5.0 MIN. TIME STEP.

---- TRANSFORMED HYETOGRAPH ----

TIME	RAIN	TIME	RAIN	TIME	RAIN	TIME	RAIN
hrs	mm/hr	hrs	mm/hr	hrs	mm/hr	hrs	mm/hr
.083	1.53	.833	27.06	1.583	6.46	2.33	2.06
.167	1.53	.917	94.77	1.667	6.46	2.42	1.68
.250	2.32	1.000	94.77	1.750	4.54	2.50	1.68
.333	2.32	1.083	36.99	1.833	4.54	2.58	1.39
.417	3.95	1.167	36.99	1.917	3.37	2.67	1.39
.500	3.95	1.250	17.18	2.000	3.37	2.75	1.17
.583	8.18	1.333	17.18	2.083	2.60	2.83	1.17
.667	8.18	1.417	9.92	2.167	2.60	2.92	1.00
.750	27.06	1.500	9.92	2.250	2.06	3.00	1.00

Unit Hyd Qpeak (cms)= .141

PEAK FLOW (cms)= .029 (i)  
 TIME TO PEAK (hrs)= 1.167  
 RUNOFF VOLUME (mm)= 11.073  
 TOTAL RAINFALL (mm)= 37.696  
 RUNOFF COEFFICIENT = .294

(i) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

```

-----
| CALIB |
| STANDHYD (0003) | Area (ha)= .70
| ID= 1 DT= 5.0 min | Total Imp(%)= 90.00 Dir. Conn.(%)= 90.00
-----

```

	IMPERVIOUS	PERVIOUS (i)	
Surface Area (ha)=	.63	.07	
Dep. Storage (mm)=	1.00	1.00	
Average Slope (%)=	1.00	2.00	
Length (m)=	68.30	40.00	
Mannings n =	.013	.250	
Max.Eff.Inten.(mm/hr)=	94.77	30.60	
over (min)	5.00	10.00	
Storage Coeff. (min)=	2.08 (ii)	5.07 (ii)	
Unit Hyd. Tpeak (min)=	5.00	10.00	
Unit Hyd. peak (cms)=	.31	.16	
			*TOTALS*
PEAK FLOW (cms)=	.16	.01	.169 (iii)
TIME TO PEAK (hrs)=	1.00	1.08	1.00
RUNOFF VOLUME (mm)=	36.70	13.44	34.37
TOTAL RAINFALL (mm)=	37.70	37.70	37.70
RUNOFF COEFFICIENT =	.97	.36	.91

\*\*\*\*\* WARNING: STORAGE COEFF. IS SMALLER THAN TIME STEP!

- (i) CN PROCEDURE SELECTED FOR PERVIOUS LOSSES:  
 CN\* = 80.0 Ia = Dep. Storage (Above)
- (ii) TIME STEP (DT) SHOULD BE SMALLER OR EQUAL  
 THAN THE STORAGE COEFFICIENT.
- (iii) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

```

-----
| CALIB |
| STANDHYD (0001) | Area (ha)= .17
| ID= 1 DT= 5.0 min | Total Imp(%)= 99.00 Dir. Conn.(%)= 99.00
-----

```

	IMPERVIOUS	PERVIOUS (i)
Surface Area (ha)=	.17	.00
Dep. Storage (mm)=	1.00	1.00
Average Slope (%)=	1.00	2.00
Length (m)=	33.70	40.00
Mannings n =	.013	.250

Max.Eff.Inten.(mm/hr)=	94.77	152.99	
over (min)	5.00	5.00	
Storage Coeff. (min)=	1.36 (ii)	2.51 (ii)	
Unit Hyd. Tpeak (min)=	5.00	5.00	
Unit Hyd. peak (cms)=	.33	.29	
			*TOTALS*
PEAK FLOW (cms)=	.04	.00	.044 (iii)
TIME TO PEAK (hrs)=	1.00	1.00	1.00
RUNOFF VOLUME (mm)=	36.70	13.44	36.46
TOTAL RAINFALL (mm)=	37.70	37.70	37.70
RUNOFF COEFFICIENT =	.97	.36	.97

\*\*\*\*\* WARNING: STORAGE COEFF. IS SMALLER THAN TIME STEP!

- (i) CN PROCEDURE SELECTED FOR PERVIOUS LOSSES:  
    CN\* = 80.0   Ia = Dep. Storage (Above)
- (ii) TIME STEP (DT) SHOULD BE SMALLER OR EQUAL  
      THAN THE STORAGE COEFFICIENT.
- (iii) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

```

-----
| CALIB |
| STANDHYD (0002) |
| ID= 1 DT= 5.0 min |
-----

```

Area (ha)=	.32		
Total Imp(%)=	99.00	Dir. Conn.(%)=	99.00

		IMPERVIOUS	PERVIOUS (i)	
Surface Area (ha)=	.32	.00		
Dep. Storage (mm)=	1.00	1.00		
Average Slope (%)=	1.00	2.00		
Length (m)=	46.40	40.00		
Mannings n =	.013	.250		
Max.Eff.Inten.(mm/hr)=	94.77	76.49		
over (min)	5.00	5.00		
Storage Coeff. (min)=	1.65 (ii)	2.79 (ii)		
Unit Hyd. Tpeak (min)=	5.00	5.00		
Unit Hyd. peak (cms)=	.32	.28		
				*TOTALS*
PEAK FLOW (cms)=	.08	.00	.084 (iii)	
TIME TO PEAK (hrs)=	1.00	1.00	1.00	
RUNOFF VOLUME (mm)=	36.70	13.44	36.46	
TOTAL RAINFALL (mm)=	37.70	37.70	37.70	
RUNOFF COEFFICIENT =	.97	.36	.97	

\*\*\*\*\* WARNING: STORAGE COEFF. IS SMALLER THAN TIME STEP!

- (i) CN PROCEDURE SELECTED FOR PERVIOUS LOSSES:  
    CN\* = 80.0   Ia = Dep. Storage (Above)
- (ii) TIME STEP (DT) SHOULD BE SMALLER OR EQUAL  
      THAN THE STORAGE COEFFICIENT.
- (iii) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

```

-----
| RESERVOIR (0202) |
| IN= 2---> OUT= 1 |
| DT= 5.0 min |
-----

```

	OUTFLOW	STORAGE	OUTFLOW	STORAGE
	(cms)	(ha.m.)	(cms)	(ha.m.)
	.0000	.0000	.0090	.0080
	.0040	.0040	.0130	.0130
	AREA	QPEAK	TPEAK	R.V.
	(ha)	(cms)	(hrs)	(mm)
INFLOW : ID= 2 (0001)	.170	.044	1.00	36.46
OUTFLOW: ID= 1 (0202)	.170	.005	1.50	34.99

PEAK FLOW REDUCTION [Qout/Qin] (%) = 10.52  
 TIME SHIFT OF PEAK FLOW (min) = 30.00  
 MAXIMUM STORAGE USED (ha.m.) = .0045

```

-----
| ADD HYD (0207) |
| 1 + 2 = 3 |
-----
                AREA   QPEAK   TPEAK   R.V.
                (ha)   (cms)   (hrs)   (mm)
    ID1= 1 (0202):   .17   .005   1.50   34.99
    + ID2= 2 (0002):   .32   .084   1.00   36.46
    =====
    ID = 3 (0207):   .49   .087   1.00   35.95
  
```

NOTE: PEAK FLOWS DO NOT INCLUDE BASEFLOWS IF ANY.

```

-----
| ADD HYD (0208) |
| 1 + 2 = 3 |
-----
                AREA   QPEAK   TPEAK   R.V.
                (ha)   (cms)   (hrs)   (mm)
    ID1= 1 (0003):   .70   .169   1.00   34.37
    + ID2= 2 (0207):   .49   .087   1.00   35.95
    =====
    ID = 3 (0208):   1.19   .256   1.00   35.02
  
```

NOTE: PEAK FLOWS DO NOT INCLUDE BASEFLOWS IF ANY.

```

-----
| ADD HYD (0209) |
| 1 + 2 = 3 |
-----
                AREA   QPEAK   TPEAK   R.V.
                (ha)   (cms)   (hrs)   (mm)
    ID1= 1 (0004):   .63   .029   1.17   11.07
    + ID2= 2 (0208):   1.19   .256   1.00   35.02
    =====
    ID = 3 (0209):   1.82   .273   1.00   26.75
  
```

NOTE: PEAK FLOWS DO NOT INCLUDE BASEFLOWS IF ANY.

```

-----
| RESERVOIR (0206) |
| IN= 2---> OUT= 1 |
| DT= 5.0 min |
-----
                OUTFLOW   STORAGE   |   OUTFLOW   STORAGE
                (cms)   (ha.m.)   |   (cms)   (ha.m.)
                .0000   .0000   |   .0240   .0539
                .0170   .0146   |   .0260   .0666
                .0200   .0276   |   .0280   .0789
                .0220   .0407   |   .0290   .0907
-----
                AREA   QPEAK   TPEAK   R.V.
                (ha)   (cms)   (hrs)   (mm)
    INFLOW : ID= 2 (0209)   1.821   .273   1.00   26.75
    OUTFLOW: ID= 1 (0206)   1.821   .021   1.92   26.63
  
```

PEAK FLOW REDUCTION [Qout/Qin] (%) = 7.66  
 TIME SHIFT OF PEAK FLOW (min) = 55.00  
 MAXIMUM STORAGE USED (ha.m.) = .0337

\*\*\*\*\*  
 \*\* SIMULATION NUMBER: 6 \*\*  
 \*\*\*\*\*

```

-----
| CHICAGO STORM | IDF curve parameters: A=5588.000
| Ptotal= 80.54 mm | B= 28.000
-----
C= 1.000
used in: INTENSITY = A / (t + B)^C

Duration of storm = 3.00 hrs
Storm time step = 10.00 min
Time to peak ratio = .33
  
```

TIME	RAIN	TIME	RAIN	TIME	RAIN	TIME	RAIN
hrs	mm/hr	hrs	mm/hr	hrs	mm/hr	hrs	mm/hr
.17	5.26	1.00	147.05	1.83	14.14	2.67	4.81
.33	7.73	1.17	77.70	2.00	10.82	2.83	4.10
.50	12.46	1.33	43.43	2.17	8.55	3.00	3.54
.67	23.45	1.50	27.74	2.33	6.93		
.83	60.52	1.67	19.25	2.50	5.73		

```

-----
| CALIB |
| NASHYD (0004) | Area (ha)= .63 Curve Number (CN)= 80.0
| ID= 1 DT= 5.0 min | Ia (mm)= 5.00 # of Linear Res. (N)= 3.00
-----
U.H. Tp (hrs)= .17
  
```

NOTE: RAINFALL WAS TRANSFORMED TO 5.0 MIN. TIME STEP.

---- TRANSFORMED HYETOGRAPH ----

TIME	RAIN	TIME	RAIN	TIME	RAIN	TIME	RAIN
hrs	mm/hr	hrs	mm/hr	hrs	mm/hr	hrs	mm/hr
.083	5.26	.833	60.52	1.583	19.25	2.33	6.93
.167	5.26	.917	147.05	1.667	19.25	2.42	5.73
.250	7.73	1.000	147.05	1.750	14.14	2.50	5.73
.333	7.73	1.083	77.70	1.833	14.14	2.58	4.81
.417	12.46	1.167	77.70	1.917	10.82	2.67	4.81
.500	12.46	1.250	43.43	2.000	10.82	2.75	4.10
.583	23.45	1.333	43.43	2.083	8.55	2.83	4.10
.667	23.45	1.417	27.74	2.167	8.55	2.92	3.54
.750	60.52	1.500	27.74	2.250	6.93	3.00	3.54

```

Unit Hyd Qpeak (cms)= .141

PEAK FLOW (cms)= .090 (i)
TIME TO PEAK (hrs)= 1.167
RUNOFF VOLUME (mm)= 40.891
TOTAL RAINFALL (mm)= 80.536
RUNOFF COEFFICIENT = .508
  
```

(i) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

```

-----
| CALIB |
| STANDHYD (0003) | Area (ha)= .70
| ID= 1 DT= 5.0 min | Total Imp(%)= 90.00 Dir. Conn.(%)= 90.00
  
```

```

-----
                IMPERVIOUS      PERVIOUS (i)
Surface Area    (ha)=          .63          .07
Dep. Storage    (mm)=          1.00          1.00
Average Slope   (%)=          1.00          2.00
Length          (m)=         68.30         40.00
Mannings n     =            .013          .250

Max.Eff.Inten.(mm/hr)=    147.05          77.27
                    over (min)    5.00          5.00
Storage Coeff.  (min)=    1.74 (ii)        4.25 (ii)
Unit Hyd. Tpeak (min)=    5.00          5.00
Unit Hyd. peak  (cms)=    .32            .23

                *TOTALS*
PEAK FLOW       (cms)=    .26            .01          .271 (iii)
TIME TO PEAK    (hrs)=    1.00            1.00          1.00
RUNOFF VOLUME   (mm)=    79.54          44.23         76.00
TOTAL RAINFALL  (mm)=    80.54          80.54         80.54
RUNOFF COEFFICIENT =    .99            .55           .94

```

\*\*\*\*\* WARNING: STORAGE COEFF. IS SMALLER THAN TIME STEP!

- (i) CN PROCEDURE SELECTED FOR PERVIOUS LOSSES:  
CN\* = 80.0 Ia = Dep. Storage (Above)
- (ii) TIME STEP (DT) SHOULD BE SMALLER OR EQUAL  
THAN THE STORAGE COEFFICIENT.
- (iii) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

```

-----
| CALIB          |
| STANDHYD (0001) | Area (ha)= .17
|ID= 1 DT= 5.0 min | Total Imp(%)= 99.00 Dir. Conn.(%)= 99.00
-----

```

```

                IMPERVIOUS      PERVIOUS (i)
Surface Area    (ha)=          .17          .00
Dep. Storage    (mm)=          1.00          1.00
Average Slope   (%)=          1.00          2.00
Length          (m)=         33.70         40.00
Mannings n     =            .013          .250

Max.Eff.Inten.(mm/hr)=    147.05          386.35
                    over (min)    5.00          5.00
Storage Coeff.  (min)=    1.14 (ii)        2.10 (ii)
Unit Hyd. Tpeak (min)=    5.00          5.00
Unit Hyd. peak  (cms)=    .34            .31

                *TOTALS*
PEAK FLOW       (cms)=    .07            .00          .069 (iii)
TIME TO PEAK    (hrs)=    1.00            1.00          1.00
RUNOFF VOLUME   (mm)=    79.54          44.23         79.18
TOTAL RAINFALL  (mm)=    80.54          80.54         80.54
RUNOFF COEFFICIENT =    .99            .55           .98

```

\*\*\*\*\* WARNING: STORAGE COEFF. IS SMALLER THAN TIME STEP!

- (i) CN PROCEDURE SELECTED FOR PERVIOUS LOSSES:  
CN\* = 80.0 Ia = Dep. Storage (Above)
- (ii) TIME STEP (DT) SHOULD BE SMALLER OR EQUAL  
THAN THE STORAGE COEFFICIENT.
- (iii) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

```

-----
| CALIB          |
| STANDHYD (0002) | Area (ha)= .32
|ID= 1 DT= 5.0 min | Total Imp(%)= 99.00 Dir. Conn.(%)= 99.00
-----

```

	IMPERVIOUS	PERVIOUS (i)	
Surface Area (ha)=	.32	.00	
Dep. Storage (mm)=	1.00	1.00	
Average Slope (%)=	1.00	2.00	
Length (m)=	46.40	40.00	
Mannings n =	.013	.250	
Max.Eff.Inten.(mm/hr)=	147.05	193.18	
over (min)	5.00	5.00	
Storage Coeff. (min)=	1.38 (ii)	2.34 (ii)	
Unit Hyd. Tpeak (min)=	5.00	5.00	
Unit Hyd. peak (cms)=	.33	.30	
			*TOTALS*
PEAK FLOW (cms)=	.13	.00	.131 (iii)
TIME TO PEAK (hrs)=	1.00	1.00	1.00
RUNOFF VOLUME (mm)=	79.54	44.23	79.17
TOTAL RAINFALL (mm)=	80.54	80.54	80.54
RUNOFF COEFFICIENT =	.99	.55	.98

\*\*\*\*\* WARNING: STORAGE COEFF. IS SMALLER THAN TIME STEP!

- (i) CN PROCEDURE SELECTED FOR PERVIOUS LOSSES:  
CN\* = 80.0 Ia = Dep. Storage (Above)
- (ii) TIME STEP (DT) SHOULD BE SMALLER OR EQUAL  
THAN THE STORAGE COEFFICIENT.
- (iii) PEAK FLOW DOES NOT INCLUDE BASEFLOW IF ANY.

```

-----
| RESERVOIR (0202) |
| IN= 2---> OUT= 1 |
| DT= 5.0 min |
-----

```

	OUTFLOW (cms)	STORAGE (ha.m.)	OUTFLOW (cms)	STORAGE (ha.m.)
	.0000	.0000	.0090	.0080
	.0040	.0040	.0130	.0130

	AREA (ha)	QPEAK (cms)	TPEAK (hrs)	R.V. (mm)
INFLOW : ID= 2 (0001)	.170	.069	1.00	79.18
OUTFLOW: ID= 1 (0202)	.170	.010	1.58	77.71

PEAK FLOW REDUCTION [Qout/Qin](%)= 14.30  
TIME SHIFT OF PEAK FLOW (min)= 35.00  
MAXIMUM STORAGE USED (ha.m.)= .0091

```

-----
| ADD HYD (0207) |
| 1 + 2 = 3 |
-----

```

	AREA (ha)	QPEAK (cms)	TPEAK (hrs)	R.V. (mm)
ID1= 1 (0202):	.17	.010	1.58	77.71
+ ID2= 2 (0002):	.32	.131	1.00	79.17
=====				
ID = 3 (0207):	.49	.137	1.00	78.67

NOTE: PEAK FLOWS DO NOT INCLUDE BASEFLOWS IF ANY.

```

-----
| ADD HYD (0208) |
| 1 + 2 = 3 |
-----

```

	AREA (ha)	QPEAK (cms)	TPEAK (hrs)	R.V. (mm)
ID1= 1 (0003):	.70	.271	1.00	76.00
+ ID2= 2 (0207):	.49	.137	1.00	78.67
=====				

ID = 3 (0208): 1.19 .409 1.00 77.10

NOTE: PEAK FLOWS DO NOT INCLUDE BASEFLOWS IF ANY.

```
-----
| ADD HYD (0209) |
| 1 + 2 = 3 |
-----
          AREA   QPEAK   TPEAK   R.V.
          (ha)   (cms)   (hrs)   (mm)
ID1= 1 (0004): .63   .090   1.17   40.89
+ ID2= 2 (0208): 1.19  .409   1.00   77.10
=====
ID = 3 (0209): 1.82  .471   1.00   64.60
```

NOTE: PEAK FLOWS DO NOT INCLUDE BASEFLOWS IF ANY.

```
-----
| RESERVOIR (0206) |
| IN= 2---> OUT= 1 |
| DT= 5.0 min |
-----
          OUTFLOW   STORAGE   |   OUTFLOW   STORAGE
          (cms)     (ha.m.)   |   (cms)     (ha.m.)
          .0000     .0000   |   .0240     .0539
          .0170     .0146   |   .0260     .0666
          .0200     .0276   |   .0280     .0789
          .0220     .0407   |   .0290     .0907

          AREA   QPEAK   TPEAK   R.V.
          (ha)   (cms)   (hrs)   (mm)
INFLOW : ID= 2 (0209) 1.821  .471   1.00   64.60
OUTFLOW: ID= 1 (0206) 1.821  .029   2.67   64.48
```

```
PEAK FLOW REDUCTION [Qout/Qin](%)= 6.13
TIME SHIFT OF PEAK FLOW (min)=100.00
MAXIMUM STORAGE USED (ha.m.)= .0890
```

FINISH

```
=====
=====
```





## Hydroworks Sizing Summary

### Proposed Senior Living Residential Development

79 Henderson St, Port Hope

02-04-2022

### Recommended Size: HydroDome HD 6

A HydroDome HD 6 is recommended to provide 80 % annual TSS removal based on a drainage area of 1.821 (ha) with an imperviousness of 65 % and Peterborough, Ontario rainfall for the 20 um to 2000 um particle size distribution.

The recommended HydroDome HD 6 treats 86 % of the annual runoff and provides 81 % annual TSS removal for the Peterborough rainfall records and 20 um to 2000 um particle size distribution.

The HydroDome has a siphon which creates a discontinuity in headloss. The given peak flow of .03 (m<sup>3</sup>/s) is less than the full pipe flow of 21.68 (m<sup>3</sup>/s) indicating free flow in the pipe during the peak flow assuming no tailwater condition. Partial pipe flow was assumed for the headloss calculations. The headloss was calculated to be 208 (mm) above the crown of the 600 (mm) outlet pipe.

This summary report provides the main parameters that were used for sizing. These parameters are shown on the summary tables and graphs provided in this report.

If you have any questions regarding this sizing summary please do not hesitate to contact

Hydroworks at 888-290-7900 or email us at support@hydroworks.com.

The sizing program is for sizing purposes only and does not address any site specific parameters such as hydraulic gradeline, tailwater submergence, groundwater, soils bearing capacity, etc. Headloss calculations are not a hydraulic gradeline calculation since this requires a starting water level and an analysis of the entire system downstream of the HydroDome .

### TSS Removal Sizing Summary

The screenshot shows the 'HydroDome Annual Sizing Results' table with the following data:

Model #	Qlow (m3/s)	Qtot (m3/s)	Flow Capture (%)	TSS Removal (%)
Unavailable	.03	.03	86 %	64 %
HD 4	.03	.03	86 %	71 %
HD 5	.03	.03	86 %	77 %
HD 6	.03	.03	86 %	81 %
Unavailable	.03	.03	86 %	82 %
HD 8	.03	.03	86 %	84 %
HD 10	.03	.03	86 %	88 %
HD 12	.03	.03	86 %	88 %

The 'Particle Size Distribution' table shows the following data:

Size (um)	%	SG
20	20	2.65
60	20	2.65
150	20	2.65
400	20	2.65
2000	20	2.65

Other interface details include: Site Parameters (Area: 1.821 ha, Imperviousness: 65%), Units (Metric checked), Rainfall Station (Peterborough, Ontario, 1971 to 2006, Rainfall Timestep: 60 min), Project Title (Proposed Senior Living Residential Development, 79 Henderson St. Port Hope), Outlet Pipe (Diam: 600 mm, Slope: 1%, Peak Design Flow: .030 m3/s), and a 'Simulate' button.

### TSS Particle Size Distribution

Hydroworks Siphon Separator Sizing Program - HydroDome

File Product Units CAD Video Help

General Dimensions Rainfall Site TSS PSD TSS Loading Quantity Storage By-Pass Custom CAD Video Other

**TSS Particle Size Distribution**

Size (um)	%	SG
20	20	2.65
60	20	2.65
150	20	2.65
400	20	2.65
2000	20	2.65
*		

**Notes:**

1. To change data just click a cell and type in the new value(s)
2. To add a row just go to the bottom of the table and start typing.
3. To delete a row, select the row by clicking on the first pointer column, then press delete
4. To sort the table click on one of the column headings


**TSS Distributions**

- Standard Design
- ETV Canada
- OK110
- Toronto
- Ontario Fine
- Calgary Forebay
- Kitchener
- User Defined

Clear

You must select a particle size distribution for TSS to simulate TSS removal

Water Temp (C)



Site Physical Characteristics

Hydroworks Siphon Separator Sizing Program - HydroDome

File Product Units CAD Video Help

General | Dimensions | Rainfall | Site | TSS PSD | TSS Loading | Quantity Storage | By-Pass | Custom | CAD | Video | Other

**Catchment Parameters**

Width (m)     Imperv. Mannings n   
    Perv Mannings n   
Slope (%)     Imp. Depress. Storage (mm)   
Perv. Depress. Storage (mm)

**Maintenance**

Frequency (months)

**Daily Evaporation (mm/day)**

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
0	0	0	2.54	2.54	3.81	3.81	3.81	2.54	2.54	0	0

**Infiltration**

Max. Infiltration Rate (mm/hr)   
Min. Infiltration Rate (mm/hr)   
Infiltration Decay Rate (1/s)   
Infiltration Regen. Rate (1/s)

**Catch Basins**

# of Catch basins

**Controlled Roof Runoff**

Roof Runoff (m3/s)

## Dimensions And Capacities

Hydroworks Siphon Separator Sizing Program - HydroDome


File Product Units CAD Video Help

General Dimensions Rainfall Site TSS PSD TSS Loading Quantity Storage By-Pass Custom CAD Video Other


Dimensions and Capacities					
Model	Diam. (m)	Depth (m)	Float. Vol. (L)	Sediment Vol. (m3)	Total Vol. (m3)
HD 3	0.91	1.22	114	0.3	0.8
HD 4	1.22	1.37	243	0.6	1.6
HD 5	1.52	1.68	442	1.1	3.1
HD 6	1.83	1.98	728	1.9	5.2
HD 7	2.13	2.29	1114	3	8.2
HD 8	2.44	2.59	1698	4.3	12.1
HD 10	3.05	3.2	3284	8.2	23.3
HD 12	3.66	3.81	5639	13.9	40

Depth = Depth from outlet invert to inside bottom of tank


### Generic HD 6 CAD Drawing




### TSS Buildup And Washoff



## Upstream Quantity Storage



## Other Parameters



Hydroworks Sizing Program - Version 5.5  
Copyright Hydroworks, LLC, 2021

# APPENDIX E


*ODAN/DETECH GROUP ENGINEERING DRAWINGS*

*CONCEPT SITE SERVICING*

*CONCEPT SITE GRADING*



# HENDERSON STREET




**CONTRACTOR TO PROVIDE AS-BUILT DRAWINGS UPON COMPLETION OF ALL WORKS TO THE ODAN/DETECH GROUP**

**CONTRACTOR TO VERIFY ALL INVERTS, SIZE, MATERIAL, AND LOCATION OF ALL SERVICES PRIOR TO CONSTRUCTION AND REPORT ANY DISCREPANCIES TO THE ODAN/DETECH GROUP**

**SERVICING LEGEND:**

●	DENOTES PROPOSED HYDRANT	○	DENOTES EXISTING HYDRANT
○	DENOTES EXISTING STORM MANHOLE	○	DENOTES PROPOSED WATER VALVE & BOX
○	DENOTES PROPOSED STORM MANHOLE	○	DENOTES EXISTING WATER VALVE & BOX
○	DENOTES EXISTING CATCH BASIN	○	DENOTES EXISTING WATER METER
○	DENOTES PROPOSED CATCHBASIN	○	DENOTES PROPOSED WATER METER
○	DENOTES PROPOSED STORMCEPTOR	○	DENOTES EXISTING WATER MAIN
○	DENOTES PROPOSED INLET CONTROL DEVICE (ICD)	○	DENOTES PROPOSED WATER MAIN
○	DENOTES EXISTING STORM SEWER	○	DENOTES PROPOSED STORM SEWER
○	DENOTES EXISTING STORM SEWER	○	DENOTES PROPOSED SIAMSESE CONNECTION
○	DENOTES EXISTING SUB-DRAIN	○	DENOTES PROPOSED CAP FOR SANITARY, STORM AND/OR WATER AS NOTED
○	DENOTES EXISTING SANITARY MANHOLE	○	DENOTES PROPOSED ENTRANCE LOCATION
○	DENOTES PROPOSED SANITARY MANHOLE	○	DENOTES PROPOSED LIMIT OF CONSTRUCTION
○	DENOTES PROPOSED SANITARY SEWER	○	DENOTES PROPOSED HEAVY DUTY ASPHALT AREA
○	DENOTES EXISTING SANITARY SEWER		



**NOTES:**  
 THE POSITION OF POLE LINES, CONDUITS, WATERMANS, SEWERS AND UNDERGROUND AND ABOVE GROUND UTILITIES IS NOT NECESSARILY SHOWN ON THE CONTRACT DRAWINGS, AND WHERE SHOWN, THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED BEFORE STARTING THE WORK THE CONTRACTOR SHALL CONFIRM OF THE EXACT LOCATION OF ALL UTILITIES AND STRUCTURES, AND SHALL ASSUME ALL LIABILITY FOR DAMAGE TO THEM.  
 THE CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS ON THE JOB AND REPORT ANY DISCREPANCY TO THE ARCHITECTS/ENGINEERS BEFORE PROCEEDING WITH THE WORKS.  
 ALL DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND THE PROPERTY OF THE ENGINEER WHICH MUST BE RETURNED AT THE COMPLETION OF WORK.  
 THIS DRAWING IS NOT TO BE SCALED. CONTRACTOR TO USE DIGITAL FILES FOR LAYOUT PROVIDED BY ENGINEER. THIS PLAN MUST NOT BE USED TO SITE THE PROPOSED BUILDINGS.  
 THE APPROVAL OF THIS PLAN DOES NOT EXEMPT THE OWNER'S CONTRACTOR FROM OBTAINING, BUT NOT LIMITED TO THE FOLLOWING PERMITS: ROAD CUT, SEWER PERMITS, RELOCATION OF SERVICES, ENCROACHMENT AGREEMENTS, APPROACH APPROVAL PERMITS, ETC.  
 EXISTING TOPOGRAPHICAL INFORMATION SUPPLIED BY SYLVESTER & BROWN LAND SURVEYING, DATED JULY 23, 2021.

**BENCH MARK:**  
 ELEVATIONS ARE GEODETIC, DERIVED BY RTK GPS OBSERVATIONS USING THE TOPNET REAL-TIME NETWORK SERVICE AND REFERRED TO CGVD28-1978 USING THE NRCAN HTV2.0 GEODID SEPARATION MODEL.

**METRIC NOTE:**  
 DISTANCES AND ELEVATIONS ON THIS PLAN ARE TYPICALLY SHOWN IN METRES AND CAN BE CONVERTED TO FEET BY DIVIDING BY 0.3048.

NO.	REVISIONS	DATE	BY
4	ISSUED FOR ZONING 2ND SUBMISSION	NOV-10-22	M.H.
3	ISSUED FOR REVIEW AND COORDINATION	FEB-11-22	G.V.
2	ISSUED FOR REVIEW AND COORDINATION	DEC-15-21	G.V.
1	ISSUED FOR REVIEW AND COORDINATION	DEC-01-21	G.V.

**CLIENT:**  
**NAUTICAL LANDS GROUP**  
 29-62 CARP ROAD  
 CARP, ON. K0A 1L0

**PROJECT:**  
**PROPOSED RESIDENTIAL DEVELOPMENT**  
 79 HENDERSON ST  
 PORT HOPE, ONTARIO

**SCALE:**  
 0 5 10 20 30  
 1:300

**ODAN-DETECH CONSULTING ENGINEERS**  
 The Odan/Detech Group Inc. P. (905) 632-3811 F. (905) 632-3363  
 5230 SOUTH SERVICE ROAD, BURLINGTON, ONTARIO, L7L 5K2

**CONCEPTUAL SITE SERVICING PLAN**


21241 (PH)  
 PROJECT NUMBER

DEC 2021  
 DATE:

DESIGN BY: G.V.  
 DRAWN BY: G.V.  
 CHECKED BY: M.H.H.  
 APPROVED BY: P.H.  
 DRWG. NO.: 1 OF 2

ENGINEER

# HENDERSON STREET




**GRADING LEGEND:**

<ul style="list-style-type: none"> <li>⊕ DENOTES EXISTING STORM MANHOLE</li> <li>⊙ DENOTES PROPOSED STORM MANHOLE</li> <li>⊠ DENOTES EXISTING CATCH BASIN</li> <li>⊡ DENOTES PROPOSED CATCHBASIN</li> <li>⊕ DENOTES PROPOSED STORMCEPTOR</li> <li>⊙ DENOTES EXISTING SANITARY MANHOLE</li> <li>⊙ DENOTES PROPOSED SANITARY MANHOLE</li> <li>⊙ DENOTES PROPOSED HYDRANT</li> <li>⊙ DENOTES EXISTING HYDRANT</li> <li>⊙ DENOTES PROPOSED WATER VALVE &amp; BOX</li> <li>⊙ DENOTES EXISTING WATER VALVE &amp; BOX</li> </ul>	<ul style="list-style-type: none"> <li>⊕ DENOTES PROPOSED WATER METER</li> <li>⊕ DENOTES PROPOSED GAMESSE CONNECTION</li> <li>⊕ DENOTES EXISTING SPOT ELEVATION</li> <li>⊕ DENOTES PROPOSED ELEVATION</li> <li>⊕ DENOTES PROPOSED TOP OF CURB ELEVATION</li> <li>⊕ DENOTES PROPOSED GUTTER LINE ELEVATION</li> <li>⊕ DENOTES PROPOSED BACK OF CURB ELEVATION</li> <li>⊕ DENOTES PROPOSED HIGH POINT</li> <li>⊕ DENOTES PROPOSED SWALE INVERT ELEVATION</li> <li>⊕ DENOTES PROPOSED ELEVATION BY OTHERS</li> <li>⊕ DENOTES PROPOSED FLOW ARROW AND SLOPE</li> </ul>	<ul style="list-style-type: none"> <li>— DENOTES PROPOSED SWALE</li> <li>— DENOTES EMERGENCY OVERLAND FLOW</li> <li>— DENOTES PROPOSED SLOPE (3:1 OR HIGHER)</li> <li>— DENOTES EXISTING CONTOUR</li> <li>— DENOTES PROPOSED SILT FENCE</li> <li>— DENOTES LINES TO MATCH EXISTING GRADES</li> <li>— DENOTES PROPOSED ENTRANCE LOCATION</li> <li>— DENOTES EXTENT OF MAX. PONDING (0.30m)</li> <li>— DENOTES PROPOSED LIMIT OF CONSTRUCTION</li> <li>— DENOTES PROPOSED HEAVY DUTY ASPHALT AREA</li> <li>— DENOTES PROPOSED SUBDRAIN</li> </ul>
---	--	---

**CONTRACTOR TO PROVIDE AS-BUILT DRAWINGS UPON COMPLETION OF ALL WORKS TO THE ODAN/DETECH GROUP**

**CONTRACTOR TO VERIFY ALL INVERTS, SIZE, MATERIAL, AND LOCATION OF ALL SERVICES PRIOR TO CONSTRUCTION AND REPORT ANY DISCREPANCIES TO THE ODAN/DETECH GROUP**



**NOTES:**

THE POSITION OF POLE LINES, CONDUITS, WATERMANS, SEWERS AND UNDERGROUND AND ABOVE GROUND UTILITIES IS NOT NECESSARILY SHOWN ON THE CONTRACT DRAWINGS, AND WHERE SHOWN, THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED BEFORE STARTING THE WORK. THE CONTRACTOR SHALL CONFIRM OF THE EXACT LOCATION OF ALL UTILITIES AND STRUCTURES, AND SHALL ASSUME ALL LIABILITY FOR DAMAGE TO THEM.

THE CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS ON THE JOB AND REPORT ANY DISCREPANCY TO THE ARCHITECTS/ENGINEERS BEFORE PROCEEDING WITH THE WORKS.

ALL DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND THE PROPERTY OF THE ENGINEER WHICH MUST BE RETURNED AT THE COMPLETION OF WORK.

THIS DRAWING IS NOT TO BE SCALED. CONTRACTOR TO USE DIGITAL FILES FOR LAYOUT PROVIDED BY ENGINEER. THIS PLAN MUST NOT BE USED TO SITE THE PROPOSED BUILDINGS.

THE APPROVAL OF THIS PLAN DOES NOT EXEMPT THE OWNER'S CONTRACTOR FROM OBTAINING, BUT NOT LIMITED TO THE FOLLOWING PERMITS: ROAD CUT, SEWER PERMITS, RELOCATION OF SERVICES, ENCROACHMENT AGREEMENTS, APPROACH APPROVAL PERMITS, ETC.

EXISTING TOPOGRAPHICAL INFORMATION SUPPLIED BY SYLVESTER & BROWN LAND SURVEYING, DATED JULY 23, 2021.

**BENCH MARK:**

ELEVATIONS ARE GEODETIC, DERIVED BY RTK GPS OBSERVATIONS USING THE TOPNET REAL-TIME NETWORK SERVICE AND REFERRED TO CGVD28-1978 USING THE NRCAN HTV2.0 GEDD SEPARATION MODEL.

**METRIC NOTE:**

DISTANCES AND ELEVATIONS ON THIS PLAN ARE TYPICALLY SHOWN IN METRES AND CAN BE CONVERTED TO FEET BY DIVIDING BY 0.3048.

NO.	REVISIONS	DATE	BY	CLIENT :
4	ISSUED FOR ZONING 2ND SUBMISSION	NOV-10-22	M.H.H.	<b>NAUTICAL LANDS GROUP</b> 29-62 CARP ROAD CARP, ON. K0A 1L0  <b>PROPOSED RESIDENTIAL DEVELOPMENT</b> 79 HENDERSON ST PORT HOPE, ONTARIO
3	ISSUED FOR REVIEW AND COORDINATION	FEB-11-22	G.V.	
2	ISSUED FOR REVIEW AND COORDINATION	DEC-15-21	G.V.	
1	ISSUED FOR REVIEW AND COORDINATION	DEC-01-21	G.V.	

**PROPOSED RESIDENTIAL DEVELOPMENT**

79 HENDERSON ST  
PORT HOPE, ONTARIO

**ODAN-DETECH CONSULTING ENGINEERS**

The Odan/Detech Group Inc. P: (905) 632-3811 F: (905) 632-3363  
5230 SOUTH SERVICE ROAD, BURLINGTON, ONTARIO, L7L 5K2

SCALE: 1:300

DRAWING: **CONCEPTUAL SITE GRADING PLAN**

21241 (PH)

PROJECT NUMBER: DEC 2021

DATE: ENGINEER


DESIGN BY: G.V.

DRAWN BY: G.V.


CHECKED BY: M.H.H.

APPROVED BY: P.H.

DRWG. NO.: 2 OF 2




EAST-WEST DRY POND SECTION  
SCALE = 1:100



NORTH-SOUTH DRY POND SECTION  
SCALE = 1:100

PROFILE VIEW POND N-S



**NOTES:**  
 THE POSITION OF POLE LINES, CONDUITS, WATERMANS, SEWERS AND UNDERGROUND AND ABOVE GROUND UTILITIES IS NOT NECESSARILY SHOWN ON THE CONTRACT DRAWINGS, AND WHERE SHOWN, THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED BEFORE STARTING THE WORK. THE CONTRACTOR SHALL CONFIRM OF THE EXACT LOCATION OF ALL UTILITIES AND STRUCTURES, AND SHALL ASSUME ALL LIABILITY FOR DAMAGE TO THEM.  
 THE CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS ON THE JOB AND REPORT ANY DISCREPANCY TO THE ARCHITECTS/ENGINEERS BEFORE PROCEEDING WITH THE WORKS.  
 ALL DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND THE PROPERTY OF THE ENGINEER WHICH MUST BE RETURNED AT THE COMPLETION OF WORK.  
 THIS DRAWING IS NOT TO BE SCALED. CONTRACTOR TO USE DIGITAL FILES FOR LAYOUT PROVIDED BY ENGINEER. THIS PLAN MUST NOT BE USED TO SITE THE PROPOSED BUILDINGS.  
 THE APPROVAL OF THIS PLAN DOES NOT EXEMPT THE OWNER'S CONTRACTOR FROM OBTAINING, BUT NOT LIMITED TO THE FOLLOWING PERMITS: ROAD CUT, SEWER PERMITS, RELOCATION OF SERVICES, ENCROACHMENT AGREEMENTS, APPROACH APPROVAL PERMITS, ETC.  
 EXISTING TOPOGRAPHICAL INFORMATION SUPPLIED BY SYLVESTER & BROWN LAND SURVEYING, DATED JULY 23, 2021.

**BENCH MARK:**  
 ELEVATIONS ARE GEDDITIC, DERIVED BY RTK GPS OBSERVATIONS USING THE TOPNET REAL-TIME NETWORK SERVICE AND REFERRED TO CGVD28-1978 USING THE NRCAN HTV2.0 GEDD SEPARATION MODEL.

**METRIC NOTE:**  
 DISTANCES AND ELEVATIONS ON THIS PLAN ARE TYPICALLY SHOWN IN METRES AND CAN BE CONVERTED TO FEET BY DIVIDING BY 0.3048.

NO.	REVISIONS	DATE	BY
4	REISSUED FOR ZONING 2ND SUBMISSION	NOV-10-22	M.H.H.
3	ISSUED FOR REVIEW AND COORDINATION	FEB-11-22	G.V.
2	ISSUED FOR REVIEW AND COORDINATION	DEC-15-21	G.V.
1	ISSUED FOR REVIEW AND COORDINATION	DEC-01-21	G.V.

CLIENT :  
**NAUTICAL LANDS GROUP**  
 29-62 CARP ROAD  
 CARP, ON. K0A 1L0

PROJECT:  
**PROPOSED RESIDENTIAL DEVELOPMENT**  
 79 HENDERSON ST  
 PORT HOPE, ONTARIO

**ODAN-DETECH**  
 CONSULTING ENGINEERS

The Odan/Detech Group Inc. P: (855) 632-3811 F: (855) 632-3363  
 5230 SOUTH SERVICE ROAD, BURLINGTON, ONTARIO, L7L 8K2

SCALE:

DRAWING :	<b>SECTIONS</b>	DESIGN BY:	G.V.
21241 (PH)		DRAWN BY:	G.V.
PROJECT NUMBER		CHECKED BY:	M.H.H.
DEC 2021		APPROVED BY:	P.H.
DATE:	ENGINEER	DRWG. NO.:	<b>5 OF 2</b>

